

NATIONAL HEALTH LABORATORY SERVICE (NHLS)

REQUEST FOR QUOTATIONS

**You are hereby invited to submit Quotation for the requirements of
National Health Laboratory service**

RFQ number:	1769725/22-23	
Closing date:	29 JULY 2022	
Closing time:	11:00 AM	
RFQ validity period:	30 days (commencing from the RFQ Closing Date)	
Important	Compulsory Site Briefing: 22 JULY 2022 @ 10H00 01 MODDERFONTEIN ROAD,SANDRINGHAM AND MEET AT NICD RECEPTION	
RFQ Description:	RESTORATION OF ELECTRICAL AND PLUMBING FIXTURES AT THE ANIMAL ANNEX BUILDING NICD, SANDRINGHAM CAMPUS	
		Hand Delivered at:
		NHLS, 1 MODDERFONTEIN ROAD, SANDRINGHAM, AT NICD STORES IN THE QUOTE BOX ON THE 29 JULY 2022 @ 11H00. (NB QUOTES THAT ARE DROPPED OFF AT NHLS QUOTE/TENDER BOX WILL NOT BE CONSIDERED

This RFQ is subject to the general conditions of the RFQ, National Treasury's general conditions of contract (GCC) and, if applicable, any other special conditions of contract (SCC).

The following particulars must be furnished
--

Information of the Bidder

Name of bidder	
Registration number	
VAT registration number	
Contact person	
Telephone number	
Cell number	
E-mail address	
Postal address	
Physical address	

I certify that the information furnished on this form is true and correct.

I further accept that, in addition to cancellation of a contract, action may be taken against me should this declaration prove to be false.

Name of bidder (duly authorised)

Signature of bidder

Date

Capacity under which this RFQ is signed

Contents

1.	<u>Terms and conditions of Request for Quotation (RFQ)</u>	5
2.	<u>Response format</u>	5
Annex A:	Response format	
Annex B:	<u>Preferential Procurement Claim form SBD 6.1</u>	8
Annex C:	<u>Tax clearance requirements SBD 2</u>	15
Annex D:	<u>Declaration of Interest SBD 4</u>	18
Annex E:	<u>Declaration of Bidders Past Supply Chain Practices SBD 8</u>	23
Annex F:	<u>CERTIFICATE OF INDEPENDENT BID DETERMINATION SBD 9</u>	25
Annex G:	<u>Government Procurement: General Conditions of Contract – July 2011</u>	28
Annex H:	<u>Local Content Declaration of the Local Content designated (SBD 6.2)</u>	
Annex I:	<u>Compulsory Briefing Attendance Certificate</u>	

TERMS AND CONDITIONS OF REQUEST FOR QUOTATION (RFQ)

- This document may contain confidential information that is the property of the NHLS and the Client. NHLS
 - No part of the contents may be used, copied, disclosed or conveyed in whole or in part to any party in any manner whatsoever other than for preparing a proposal in response to this Bid, without prior written permission from NHLS Ltd and the Client.
 - All Copyright and Intellectual Property herein vests with NHLS and its Client.
 - Late and incomplete submissions will not be accepted.
 - Price Declaration must be completed, and should the total RFQ prices differ; the one indicated above shall be considered the correct price.
 - Any bidder who has reasons to believe that the RFQ specification is based on a specific brand must inform NHLS before RFQ closing date.
 - Bidders are required to submit a valid Tax Clearance Certificate and Tax clearance verification PIN, for all price quotations exceeding the value of all the RFQ's. Failure to submit the Tax Pin and valid Tax Clearance Certificate will result in the invalidation of this RFQ.
- It is the responsibility of the bidder to ensure that NHLS is in possession of the bidder's valid Tax Clearance certificate. The onus is on the bidder to ensure that NHLS receives a valid Tax Certificate as soon as the validity of the said certificate expires.

- A compulsory/non-compulsory pre-proposal RFQ/site meeting will be conducted at **[01 MOODERFONTEIN ROAD SANDRINGHAM NICD RECEIPTION]** on the **22 JULY 2021**, at **[10h00]** for a period of ± hours. The briefing session will start punctually and information will not be repeated for the benefit of Respondents arriving late.
Respondents arriving after the allocated time of the briefing session and failing to attend the compulsory RFQ/Site briefing will be disqualified
- No services must be rendered or goods delivered before an official NHLS Purchase Order form has been received.
- This RFQ will be evaluated in terms of the 80/20 preference point system prescribed by the Preferential Procurement Regulations, 2011.
- All questions regarding this RFQ must be forwarded to the buyer within 24 hours after the RFQ has been issued.
- It is the responsibility of the bidder to ensure that its response reaches NHLS on or before the closing date and time of the RFQ.

FOR HAND DELIVERIES OF RESPONSES, PLEASE SUBMIT THE RFQ DOCUMENT TO NICD STORES RFQ BOX.

PLEASE DO NOT SUBMIT RFQ RESPONSES IN THE TENDER BOX AS THE RFQ RESPONSES DEPOSITED IN THE TENDER BOX SHALL NOT BE CONSIDERED.

The Bidder accepts the above terms and conditions and the General Conditions of Contract attached in Annex G .	Accept	Do not accept

2. RESPONSE FORMAT

2.1 BIDDERS SHALL SUBMIT PROPOSED RESPONSE IN ACCORDANCE WITH THE SPECIFIED BELOW. FAILURE TO DO SO SHALL RESULT DISQUALIFICATION THE BIDDER'S RESPONSE.

2.2 Schedule Index

2.2.1 Schedule 1: RFQ document

2.2.2* Schedule 2: valid Tax Clearance Certificate and Tax verification PIN

2.2.3 Schedule 3: Price (Submit the price in a sealed envelope.)

2.2.4 Schedule 4: Preferential Procurement Claim form and the **Certified copy of the B-BBEE Status Level Verification Certificate (SBD 6)**

2.2.5 Schedule 5: Declaration of interest **(SBD 4)**

- 2.2.6 **Schedule 8:** Declaration of Bidders' past supply chain practices **(SBD 8)**
- 2.2.7 **Schedule 7:** Certificate of independent bid determination **(SBD 9)**
- 2.2.8 **Schedule 8:** General Conditions of Contract
- 2.2.9 **Schedule 9:** Local Content Declaration of the Local Content designated **(SBD 6.2)**
- 2.2.10 **Schedule 10:** Attendance Certificate for a compulsory briefing session, if applicable

1. Administrative Compliance

The following will be used to evaluate bids administratively:

- Fully completed and signed SBD4
- Submission of and valid tax clearance and Tax Verification Pin
- Proof of registration on Central Supplier Database (CSD)
- Preferential Procurement Claim form
- Copy of the B-BBEE Verification Certificate(s) issued by an authorised body or person, or a sworn affidavit prescribed by the B-BBEE Codes of Good Practice.
- The service providers to have agree with NHLS general contract terms conditions

- 1.2 Next step of evaluation is the “technical” or so called “functional” evaluation, which is purely based on NHLS specifications and Scope of Work. NHLS end-user department (who *requested the RFQ*), Procurement Services, Finance and subject specialists are part of the Cross Functional Evaluation Team (CFET) meeting which is chaired by the Procurement Officer **Functionality** is the technical evaluation of the bidders' proposal.

Should functionality be included in the RFQ as a threshold, the RFQ document must clearly state the minimum score to be achieved if bidders are to be further evaluated on price and preference. Responses that do not meet the threshold for technical will not progress further.

(if applicable)

- 1.3 The final stage of evaluation is done after the CFET has reached their verdict and is done by NHLS Procurement Services. B-BBEE score (commercial evaluation) is added in order to get the final order of merit for the bidders being evaluated.

- 1.3.1 The evaluation of the Proposal shall be based on the price and B-BBEE scorecard

Price points	80
B-BBEE status level contribution	20
Total	100 points

FORM OF QUOTATION**SUPPLIER:****QUOTATION NO:****DESCRIPTION: RESTORATION OF ELECTRICAL AND PLUMBING FIXTURES AT THE ANIMAL ANNEX
BUILDING NICD, SANDRINGHAM CAMPUS**

No	Description	Unit	Quantity	Rate	Cost Excl. VAT
	General	x	x	x	x
1	External Walls and Façade Using a suitable high pressure washer and/or jet spray (i.e. Karcher k4 or better), thoroughly spray down the walls to the effect that any laitance, dust, grime be it bird droppings or other are cleaned satisfactorily. The high pressured cleaning should be extended to the removal of any loose plaster and or flaking paint layers or related finishing products.	SUM	1		
2	Remove any redundant materials and discard or relocate as advised by the NICD PM. Clear any overgrown vegetation including trimming the grass, shrubs, plants, trees or related for the betterment of the facility. Cart away any waste material. NB: Where fixtures are under consideration for reinstatement or future use, clean and restore such elements as neatly as possible using suitable mountings and accessories as necessary e.g. gas lines. Replace any damaged taps as necessary.	SUM	1		
3	Make good walls, columns, beams and any structural masonry, steel and/or concrete elements for the betterment and aesthetics of proposed facility from floor/ground level up to the ceiling/roof for painting/ application of a finishing product. Include the reinstatement of any missing and/or damaged brick work, staircases, balustrades and any	SUM	1		

	elements as necessary.				
4	Sand down to base metal the balustrade(s) or handrails in the staircase. Prime balustrade with red oxide paint or similar corrosion protection. Apply 2 coats of Dulux Quick-Dry Enamel High Gloss Paint suitable for all metal surfaces. Ensure painted surfaces do not have streak marks and that the final coat enhances the aesthetics of the building. Colour – Spaceship Grey.	SUM	1		
5	Apply a suitable outdoor light or mid grey epoxy resin over the exposed concrete staircase and related. Post application, the epoxy should maintain the adequate coefficient of friction through its natural life, UV resistant, slip resistant, does not flake or delaminate, apply a suitable 100mm coving as necessary. Where the concrete elements overlap or require the inclusion or intermediate or adjacent walls, attend to such elements as part of the staircase to uphold the aesthetics and the betterment of the facility as necessary. Use suitable bonding agents as necessary.	SUM	1		
6	Supply and Install 50mm wide, self-adhesive, hard wearing, black, ultra-reflective, high grip and anti-slip edging strip on staircase step side. Include landings as necessary. Strip edges should be rounded, 20mm from nosing, centred at 100mm on either side where installed. Ensure uniform and neat installation with appropriate floor preparation and that no delamination occurs post installation. Use single continuous strips i.e. no splicing of strips within a single length of installation.	SUM	3		
7	For the patio or entrance/exit, prepare floor to desired roughness and integrity, supply and install suitable slip resistant outdoor tiles with a 10mm edging strips. Consider Kilimanjaro Eagle Wood Grey EcoTec Matt Porcelain Floor Tiles or Similar Wood Look Tiles. Include all accessories as necessary including a suitable bonding agent.	SUM	3		

8	<p>External Drainage:</p> <p>Remove all existing gutters, downpipes, end plates and cart away. Install new galvanised industrial type or high catchment square gutters and downpipes as per the previous profile.</p> <p>Ensure that the gutters' slope is adequate to prevent the stagnation of rainwater. Gutters and down pipes are to be held firmly in place using anchors and/or brackets spaced @~1.5m apart.</p> <p>Place suitable concrete channels at the end of downpipes to serve as energy breakers for high velocity discharge.</p>	SUM	ALL		
9	<p>Roof:</p> <p>Remove the current installation of barge, fascia and underside boards and cart away. Provide suitable replacements that will be equally functional yet still complement existing infrastructure and uphold the aesthetics of the facility. All installations should be aligned and neat.</p> <p>Where supports for any of the boards are inadequate, provide such supports as necessary. Tie ins of old and new installations should be seamless and/or not show a discontinuity in any manner.</p> <p>Restore damaged tiles and neatly realign any pieces that may have moved during the infrastructure's use. Ensure that the roof does not leak, or makes allowances for external items such as dust, leaves or related. The complete and final alignment of roof tiles and the various boards should serve as a functional bird and dustproofing mechanism and that all redundant apertures are attended to as necessary.</p>	SUM	ALL		

10	Waterproofing: Using appropriate duramesh membranes, flashings, wedges and light grey UV stable waterproofing applicant, place waterproofing/flexikote onto the prepared structure's surface as necessary. Ensure that all overlaps and splices are accommodated and receive generous waterproofing coverage as necessary to prevent forming weak spots.				
11	Painting/Finishing: Roof – Prepare the tiles, barge and fascia boards to receive paint. Apply 2 coats <i>Plascon 48 DC 16 Tribecca Corner</i> on the tiles and trim the barge and fascia boards with <i>the Plascon 45 DC 15 Aluminium Snow</i> Concrete Elements – for beams, slabs, columns and Plinths, prepare wall to receive paint as necessary. Apply 2 coats white Waterbased undercoat to break the old rustic shade. Apply 2 coats Plascon 46 DC 16 Bali Deep. Facebrick – prepare facebrick to receive suitable top or finishing coat. Liberally apply facebrick dressing/sealant and/or stoneshield colour enhancer suitable for masonry. The product should be non sheen and also not form any surface film. The application should enhance the natural colour of the face brick.	SUM	ALL		
12	Lighting and Electrical Installations: Internal – Thoroughly clean existing fittings including glass casing and aluminium casing and replace/convert the internal florescent mechanism and tubes including ballast with suitable LED mechanism and lamps. Properties to be used as a guide are as follows: 4x27W x 2No. (600x600mm) or 3x40W x 1No. (1200x600mm) Recessed Parabolic Ceiling Light Fitting. Fully Fitted as per SANS 10400 and/or SANS 10114-1:2005 with Appropriate	SUM	ALL		

<p>LED Lamps.</p> <p>The Light Fixture Should have the following Properties as Minimum:</p> <p>Material: Mild Steel</p> <p>Supply Voltage: 230VAC</p> <p>Lamp Holder: T8</p> <p>Reflector Material: German Aluminium</p> <p>Ballast: Electronic for Flourescent and N/A for LED</p> <p>Protection Rating: IP 20</p> <p>Dimmable: No</p> <p>External:</p> <p>i. Supply and install 8no. @200W LED Slim Line Floodlights, total 26klumens or 130lumens/watt and 400W HID with IP Rating IP65. Unit should be suitable for external use and have a mounting bracket. Colour – Cool White</p> <p>ii. Supply and install 8no. @50W external Radiant LS384 wall light fixtures suitable for outdoor use. 90mm Dia with Protection Rating: IP 54. Die Cast Aluminium Casing, Depth = 140mm, height = 160mm, Colour = Cool white.</p> <p>iii. Supply and install 3no. Day and Night Switches. Allocations to be split between i. and ii. With the extra switch reserved as a spare part.</p> <p>NB – general: Where a light fixture cannot be salvaged or restored to full functionality, replace such a fixture with an appropriate fixture as per the specification above or equivalent as agreed by NICD PM. The lightning protections system risk analysis and installation safety report will be certified by means of the Certificate of Safety to the IEC 62305 Series</p> <p>All external installations should have dedicated and suitably sized circuit breakers in the internal DB. All cables should be covered with a 25mm galvanised steel bosal tube neatly</p>				
---	--	--	--	--

	mounted on the wall/structure. All termination points to have suitable plugs as necessary. Where the structure discontinues, a flexi pipe should be used to link 2 or more bosal tubes. No cables are to be exposed to weather elements.				
13	<p>Light Switches and Sockets:</p> <p>Remove current installations and cart away. Supply and Install Vetri Morden Slim Design with Bevelled Edges and Alluring White Matt. Suitable for Residential and Commercial Use.</p> <p>Material: Poly Carbonate with hidden mounting and illuminating/fluorescent indicator. Sockets to have the following configuration: USB Port, 2 Pin Plug and 3 Pin Plugs – each with dedicated isolators for individual control.</p> <p>NB – general: Ensure that all electrical wiring meets the minimum applicable performance standards as per SANS 10141-2 Part 1: Low Voltage Installations and the following IEC Series:</p> <p>IEC 60079; 60721; 60071 Parts 1 to 4; 60909-0; 61008-1; 62052-11; 62305-3 and any other standards deemed applicable.</p>	SUM	ALL		
14	<p>Remove current electrical installations and blank out redundant points using approved methods. Supply and install Grey double compartment PVC Electrical Power and Data Skirting to be mounted conveniently above laboratory work benches. The Skirting should be complete and fully functional with the following:</p> <ul style="list-style-type: none"> • Necessary Network Cabling, fittings and accessories. • Connection points for phone @1No. • Connection point for data @ 6No. 	No.	7		

	<ul style="list-style-type: none"> Electrical sockets connected to Red Plugs with 3 Pin domestic use. These should be connected via the main DB with dedicated adequately sized breaker or as necessary and evenly distributed along skirting as advised. @10No. Ensure there is provision to connect 4 Red Plugs to dedicated 20 AMP Circuit Breakers in preparation for the use of large equipment. Plug configuration to be advised prior to installation. Electrical sockets connected to normal 3 Pin plugs for domestic use. Each socket point is to have 3 Pin Plug, 2 Pin Plug and a USB Connection for convenience to the end user. There are to be neatly installed next to the Red Plugs @10No. Where workbenches are also installed in the centre of the lab, a suitable system from providing services to such benches should be employed. This could be in the form of hideaway plugs/points under the table and cabling supported by a suitable cable tray/basket. The services can also be fed through a ceiling pole or as necessary for a fully functional but aesthetically pleasing outcome. <p>NB: There will be a requirement to demonstrate that ALL connection points (data/phone/electrical and otherwise are fully functional prior to the issuing of a completion certificate or acceptance of works by the NICD PM</p>				
15	<p>Workbenches and/or Worktops:</p> <p>Supply and Install Laboratory workbenches with the following properties:</p> <ul style="list-style-type: none"> Chemical resistant Pure White Formica Top Minimum 20^{mm} thick and 750^{mm} wide mounted on 32^{mm} Black Powder Coated Steel Square Tubing with height adjustable floor protection caps or equivalent and adequate bracing on the structural frame. Operating height of work bench is 900^{mm}. 	m	50		

	<ul style="list-style-type: none"> • Work benches are to be neatly/expertly installed from corner to corner and flush with the walls. • Extensions and/or Connections to work benches should be at corners. Such connections should be neatly concealed by an appropriate decorative Pure White Metal Edging Strip • Exposed edges or edges closer to the end user should be rounded. • Termination Points are to have edging strips made of the same material as the workbench top to be installed as necessary. • All interfaces whether it's with the walls, adjacent or otherwise, should be neatly finished off with a white acrylic or paintable silicon lining. The silicon should be rounded with a licking stick dipped in a soap solution for a smooth and rounded finish. Ensure that there are no streak lines are. <p>NB: Wash basins in <u>16 below under Internal Drainage</u> will be mounted on 10m linear length of worktop.</p>				
16	<p>Internal Plumbing and Drainage:</p> <p>General</p> <p>Trace potable water mains and install a suitable sized ball valve. Where such a Mains is enclosed in a ceiling, on the roof, unavailable or not easily accessible, create a loop or offset, as necessary by maintaining the same diameter piping and installing the ball valve where it can be easily accessed in cases of emergency. Supply and install all fixtures, fittings and accessories as necessary. Show flow direction using a permanent inscription and the correct convention.</p> <p>Laboratories</p> <ol style="list-style-type: none"> 1. Remove the existing wash basins and replace with newly supplied and fitted deep bowl stainless steel laboratory sink SSC201 Series (Single station) @500x 440 x 400mm (hwxh) or suitable equivalent. x 6no. 2. Supply and install either a table top or wall mounted 	SUM	6		

	<p>elbow Cobra steel medical mixer 515/015-21 wall type or equivalent. Ensure full functionality and connection to the cold and hot water as necessary. Include all fittings, fixtures, mountings and accessories Ensure Full Functionality as per SANS 10400 and Manufacturer's Specification: Installation to Include appropriate or suited Rounded Chrome or Polished SS, Free Standing Sprout Mixer with Top Mounted Single Lever and Fixed in Position. Mixer to adequately clear basin wall, lip and should enable full and unrestricted use of basin and mixer, yet maintain desired aesthetics. Mixer to correctly indicate direction of H/C Water through appropriate colour or inscription. Sprout to have removable/changeable filter that will ensure a more laminar and directed flow towards the basin without splatter. Mixer: 1/2 Inch with an angle of <25 Degrees at Qmax against the Vertical Axis x6no.</p> <p>3. Replace all existing floor drains with suitable galvanised steel Bain drains with a water retainer for odour management. Where the existing channel drain is inefficient, ensure that the slope is corrected as necessary. All channels are to be covered with a suitable recessed GS mentis grating. Ensure that the entire system is safe and fully functional and that it does not cause a tripping hazard to the end user.</p> <p>4. Supply and Install wall mounted hand washing basin (<i>Aria Guest Bathroom Basin or Equivalent – Small; Dimensions - (400x420x140mm) with a modern elbow mixer (COBRA NM-851 ELBOW ACTION BASIN MIXER 15MM</i> with filter for regulated laminar flow - <i>Medical single lever, elbow-action basin mixer, chrome. Includes: progressive cartridge, and 1/2" BSP female inlets</i>) with all pipes, connections, accessories, valves and fittings to ensure full functionality. Consider using a stainless steel type bottle trap and ensure that all fixtures, fittings and components are considered as per SANS 10400 and any related or</p>				
--	--	--	--	--	--

	<p>applicable standards. Water supply pipes are to be neatly surface mounted, painted to blend in with the wall, and that the mounting preserves the aesthetics and unimpeded use of the laboratory and any equipment contained therein. Connect mixer to mains. Ensure mixer has an adequate supply of hot and cold water, at the correct pressure as per SANS 10400.</p> <p>Account for the supply and installation of 1m² tile splash back with appropriate decorative chrome edging strip as necessary. The splash back should be based on the following:</p> <ul style="list-style-type: none"> • Blanco Biselado Gloss Glazed Ceramic Wall Tile • 100 x 200mm Slates with Beveled Edges • Bevel Edges to be flush. No Grout Lines <p>NB: Ensure that all installations are fully functional as necessary.</p>				
17	<p>Kitchen</p> <p><i>Cupboard</i></p> <ol style="list-style-type: none"> 1. Top Cupboards – Glossy white casement doors with Gola handles on textured Sahara wood on similar body with upvc edging. Soft close hinges with adjustable 2 shelves. 2. Bottom Cupboards – Textured Sahara wood on similar body and edging. Casement doors with Gola handles. Soft close hinges. With 2 adjustable shelves. 3. Unit to be mounted on 100mm stilts covered by an aluminium skirting. 4. SS Single Bowl Complete with Full Installation Kit, Drainage, Plugs, Mountings, Fittings and Fixtures to Ensure Full Functionality as per SANS 10400 and Manufacturer's Specification. Sink to be firmly mounted under a 20mm Ceasarstone countertop with bevelled edges. <p>Installation to Include appropriate or suited Rounded</p>	SUM	1		

	<p>Chrome or Polished SS, Gooseneck Swivel Mixer with Bottom and Side Single Lever and Fixed in Position in the middle of the centre waste bowl. Mixer to adequately clear adjacent fittings to enable user's full and unrestricted use of basin and mixer, yet maintaining desired aesthetics. Mixer to correctly indicate direction of H/C Water through appropriate colour or inscription. Sprout to have removable/changeable filter that will ensure a more laminar and directed flow towards the basin without splatter.</p> <p>Dimensions are as follows:</p> <p>5. Sink:</p> <p>Effective Depth = >157mm</p> <p>Single Bowl : 410x343mm</p> <p>Centred Insert: 160 x 280mm</p> <p>Waste: 90 Dia.</p> <p>Mixer: 1/2 Inch with an angle of <15 Degrees at Qmax against the Vertical Axis.</p> <p>Material: SS</p> <p>Gooseneck Mixer:</p> <p>Base: 55 Dia</p> <p>Gooseneck: 24 Dia.</p> <p>Distance between base and Topmost part of Gooseneck: 420mm</p> <p>Distance between base and Sprout: 290mm</p> <p>Material: Chrome or Polished SS mounted on the countertop with free swivel</p> <p>Install glossy modern tiles as splashback. Design to complement modern kitchen.</p> <p>Accessories – Supply and install/fit the following:</p> <ul style="list-style-type: none"> • Fridge- Model H415BMI-WD; <i>Color – Black; Water Discharge on door; Volume – 305 Liters</i> • Microwave - <i>42 Liter Neo Chef with smart inverter system, anti-bacterial and easy clean, touch controllers; Color – Black</i> 				
--	--	--	--	--	--

	<ul style="list-style-type: none">• ZIP Hydro boil complete with all accessories as necessary for full functionality (7.5 Litres); <i>Brushed Stainless Steel Finish, LCD Screen with temperature display, modern look, mains and drainage pipes should not be visible.</i>• Under counter compact geyser, Prisma, (Dimensions = 320x 350x350mm), Weight = 8.1kg <p>Walls - Preparation</p> <p>If painting a new wall, ensure the plaster is completely dry and adequately cured before priming wall. Clean the surface to remove dirt, dust, laitance and ensure an even and smooth plaster finish or that plaster defects are corrected prior to priming. Use a mist coat to seal the wall voids to show any defects or unevenness/imperfections for filling or sanding down until entire wall is one continuous and even surface. Ensure a builder's tape, sheets and all necessary protection is applied to prevent undue paint damage to other structures.</p> <p>Exposed Walls for painting:</p> <ol style="list-style-type: none">1. Dulux Plaster Primer2. Dulux Undercoat - All Surfaces White Waterbased Sheen3. Dulux Luxurious Silk. Mineral Haze 3 Waterbased Sheen <p>NB: Ensure that all installations are fully functional as necessary.</p>				
	<p>Bathroom</p> <p>Temporarily remove any obstructions such as doors, transition strips/thresholds, furniture or any existing installations that may prevent the continuous and seamless installation of desired flooring product and/or screed, as necessary. Reinstate after. Where removed units such as doors and related fixtures and fittings are damaged and warrant a replacement, replace as necessary for the betterment and/or enhancement of the facility's aesthetics and ensure such products have full functionality. Clean off</p>				

<p>any laitance and reinstate as necessary.</p> <p>Break and remove the current bathroom including the dividing walls and cart away from site. Prepare the floor/area for brick laying, ensure the floor/wall is clean, dust and laitance-free, level/plumb, pre-wetted and clear of any residue from previous flooring system installation. Where a new wall ties in with an existing brick wall, ensure adequate structural integrity of the new wall is achieved by either toothing or using Brick Wall Ties as per SANS 10400. Apply rhinolite where an old wall plaster is uneven to achieve a smooth finish. Ensure minimum thickness is achieved as per manufacture's recommendations to avoid premature flacking or delamination.</p> <p>220x105x73mm NFP Clay or Cement Bricks, Inclusive of all ancillary requirements such as building and plaster mortar, brickforce, dampproof course, bonding agents and rhinolite</p> <p>Ensure minimum ceiling height of 2400mm as per SANS 10400. Ensure adequate brickforce is installed for every 4 courses and adequately tied in as per SANS 10400 with a minimum 2 brick length splices. Joints to be butted (for NFP and jointed for FP and NFPX) and 10mm thick with neat and clear vertical and horizontal profiles. Excess building mortar to be cleaned off prior to plastering. Brick wall to be primed with applicable bonding agent as per manufacturer's specification. Ensure a 10mm even, level and steel finish plaster. Walls to be plumb and joined at perfect 90 Degree Angles and smoothed with an appropriate rounded edging tool. Where continuous walls are desired, ensure a seamless connection and full mortar contact between bricks. For vertical walls, a maximum lift of 1200mm per 6000mm run is to be enforced per day. Induce a 20 x 15mm expansion joint complete with jointex or 3x 3mm mensonite boards or filler foam. Allow recess to accommodate backing cord and Joint Sealant (Polyurethane or Polysulphide) to be neatly smoothed with a licking stick lubricated with mild solution</p>				
--	--	--	--	--

	<p>of soap and water.</p> <p>Finishes:</p> <p>Continue with the tiles right through from the floor to the ceiling.</p> <p>New configuration:</p> <ul style="list-style-type: none"> <p><i>1no. Unisex toilet with the following.</i></p> <p>Complete Geberit Toilet Set - Wall Hung Squared Toilet Pan, Suited Squared Soft Close Seat and Cover, Wall Mounted Brushed SS Flush Plate (Geberit or Grohe) with All Fixtures and Fittings for Full Functionality.</p> <p>--</p> <p>Dimensions: 350x480x340mm (HxLxW) or similar</p> <p>NB: For every Complete toilet installation, ensure atleast 1 cubicle has the following: ITD Chrome or Polished SS Wall Mounted Bidet Shower Set with Angle Valve and Pressure Regulator/Trigger Spray Set with All Accessories and Fittings. Ensure The Showerset does not drip. All Installations as per SANS 10400 and Manufacturer's Instructions.</p> <p>1no. Disabled toilet toilet</p> <p>Consider installing the closest design to the unisex option depending on infrastructure. All Installations to meet the minimum requirements and standards applicable to toilets for disabled persons. Include all fittings, fixtures, hand rails, levers, support mechanisms as necessary for full functionality.</p> <p>3no. Handwash basins</p> <p>Symmetric Ceramic Square 0TH Basin Complete with Full Installation Kit, Drainage, Plugs, Mountings, Fittings and Fixtures to Ensure Full Functionality as per SANS 10400 and Manufacturer's Specification. SS Bottle trap, basin mounted on the wall and self</p> 				
--	--	--	--	--	--

	<p>supporting.</p> <p>Installation to Include appropriate or suited Rounded Chrome or Polished SS, Free Standing Sprout Mixer with Top Mounted Single Lever and Fixed in Position. Mixer to adequately clear hand basin wall, lip and should enable full and unrestricted use of basin and mixer, yet maintain desired aesthetics. Mixer to correctly indicate direction of H/C Water through appropriate colour or inscription. Sprout to have removable/changeable filter that will ensure a more laminar and directed flow towards the basin without splatter.</p> <p>---</p> <p>Dimensions are as follows:</p> <p>Basin: 405x405x150mm (LxWxH)</p> <p>Effective Depth = 115mm</p> <p>Mixer: 1/2 Inch with an angle of <25 Degrees at Qmax against the Vertical Axis.</p> <ul style="list-style-type: none">• Shower Cubicle Prepare installation area complete with tiling, floor drainage and the necessary plumbing and staging to receive a shower cubicle. Supply and install a frameless tempered glass shower cubicle with pivot door and SS accessories for full functionality. Install a suitable SS Grohe Lineare Shower mixer with waterfall rose, floor drain, robe hooks and towel racks.• 5no. Mirrors Black/Invicta Grey or Similar Framed Silver Mirror fully mounted on the wall and clear of any obstructions and with access to adequate lighting for the benefit of the user. All mirrors are to be 4mm thick with a 2.5mm Bevel visible on Mirror and terminated inside the Frame. Installation should be in such a manner that screws and any other wall mounting accessories should not be visible to the				
--	---	--	--	--	--

	<p>end user and installation to uphold the aesthetics of the unit at all times. The choice of mirrors agreed on should be consistent for the entire project for both full and half-length mirrors and should, as far as possible ,resemble or mimic the benchmark set by the NICD PM.</p> <p>----</p> <p>Full Length Mirror</p> <p>Dimensions: 560 x 1600mm (W x H)</p> <p>Other Properties: Mist Free/Moisture-Proof and to clear 150mm off the Top of Tiles</p> <p>Half Length Mirror</p> <p>Dimensions: 565 x 770mm (W x H)</p> <p>Other Properties: Mist Free/Moisture-Proof and to adequately clear any fixtures such as basin and taps however still ensuring full functionality for the end user.</p>				
18	<p>Floor – Entrance Area, Kitchen, Office and Bathroom</p> <p>Remove existing floor product and related accessories and cart away. Prepare the walls and floor to the desired roughness and correct/repair all surface defects, cracks and floor level as necessary. <u>You may need to use a suitable screed or similar material with suitable priming agent to achieve desired floor levels</u>, as necessary. Ensure that such preparations do not adversely affect items that will remain installed or outside the scope of works.</p> <p>Prepare the floor to the desired roughness and level. Ensure such preparations do not affect items that will remain installed or outside the scope of works</p> <p>Supply and install 490x242mm (8 faces) Northwood Natural NW-330 ceramic tiles, and all required tiles adhesive materials with light grey grouting. Include edging materials and all necessary materials to complete tiling.</p> <p><i>Edging Strips</i></p>	SUM	ALL		

	<ul style="list-style-type: none"> •Type: Square/Rounded •Material: Aluminium or Stainless Steel •Finishing: Polished Silver or Equivalent •Size: 10mm <p><i>Transition Strips on Door Threshold</i></p> <ul style="list-style-type: none"> •Type: Flat, Saddle (Upheaved) or Ramp •Finishing: Ribbed •Material: Aluminium or Stainless Steel 				
19	<p>Supply and install Split System Air-conditioning Units. Consider Samsung, York, LG, Midea, Neocool or Similar. Provide all accessories, fixtures and fittings and ensure full functionality as per applicable standards. The installation should complement the aesthetics of the new office design and wash bay areas.</p> <ul style="list-style-type: none"> • 12 000 BTU (office) • 36 000 BTU (washbay) 	no	2		
20	<p>Replace all damaged, discolored, disfigured ceiling panels as necessary. The replacement should include panels that a total contrast in color shade with the majority of the installed panels in a specific room. This essentially means all ceiling panels should be reasonably close in color and texture and should be structurally sound in order to be retained, otherwise they should be replaced.</p>	SUM	ALL		
	<p>Remove the existing double door including frame and related accessories and cart away. Modify wall, Supply and fit White uPVC Double Glazed Doors.</p> <p>The uPVC Door should have the following qualities as minimum:</p> <ul style="list-style-type: none"> • Energy efficiency i.e. low thermal transfer • Safe and Secure • Sturdy, Tough and Durable • Maintenance Free • Noise Reduction Capabilities (Sound Transmission Class) STC of ~44 dB or Comparable <p>The Door is to be neatly mounted/anchored into the existing walls/masonry. The installation should be of high quality as</p>	no	4		

	<p>per applicable, SABS 1553-1, 2007; SANS 10400 specifications with even spacing right round with weather and transition strips. The installation should be complete with all applicable ironmongery, locks, suitable door frame, Chrome half-moon magnetic door stoppers, fittings, attachments, and all applicable utilities designed to render optimal functionality thereof. Apply opaque frosting film on the entire Fixed door panel and on the bottom half of the main access door panel. The top half of the main access door panel should have decorative design/decals of the same opaque frosting material however the clear patches should be sufficient enough to serve as a viewing panel. Frosting Design detail to be discussed with NICD PM.</p> <p>Ironmongery</p> <ul style="list-style-type: none"> • Door Closure: Cam Action, TS93G, Closing Force - EN2-5V - Adjustable. • All other accessories and fittings as per manufacturer's recommendation. <p>NB: Please note that any dimensions provided are only indicative and for information. The contractor is encouraged to take their own measurements for manufacturing and construction as well as conduct a site analysis prior to quotation and/or execution.</p> <p>Where a door or doors require a shopfront installation for full functionality. Consider installing such shopfronts as necessary. Details will be provided in-depth by the NICD PM during the briefing session.</p>				
21	<p>Remove existing concrete covers and replace with suitable metal gratings. Ensure that the grating is adequately supported by angle irons to prevent undue damage to the channel.</p> <p>NB: Applicable to the road and side walk channels.</p>	SUM	ALL		

22	<p>Office:</p> <p>Break open wall/partition from the main entrance. Prepare wall to receive doorframe as necessary. Supply and install Swartland Hardwood Pine Solid Timber Door or Internal Double Masonite Solid Door complete with suitable door frame and related fittings and fixtures. Class A Fire Door for Internal Use with the following Properties:</p> <p>Dimensions: 813x2032x40mm</p> <p>Fire Rating: 1 Hour</p> <p>Integrity: 30 Minutes</p> <p>Insulation: 30 Minutes</p> <p>Colour – White</p> <p>Ironmongery</p> <ul style="list-style-type: none"> •Door Closure: Dorma TS 93G •Door Handles: Dorma Tubular SS TH125 •Door Hinges: 3x Certified (To suit) •Escutcheons: SS Cylinder DCE-002 •Mortice Lock: Narrow Stile Sash Lock DO2625 25mm Backset •Cylinder: 5 Pin Security, Knob, Nickel Plated 65mm DKC056501 •Striker Plate/Rebate Kits: To suite - D038R/D039R/D072EC •Door Stop: Half Moon SS DDS-SS-017 •Door Holder: Dortello or Similar Magnetic Holder/Latch •Signage: TBA <p>NB: Ensure that parts are ordered in the correct set quantities as well as correct installation sides. Ensure new fire door installations are matched with similar rated 1.6mm Mild Steel Double Rebate Door Frames with 3x Certified Hinges and that ALL fixtures are to suite installation prior to procurement and/or Installation. Ensure installed door is as less disruptive as possible to the general functions of the area in question</p>	SUM	1		

	when in use i.e. the door should not get in the way of user and/or others during operation (Door to open towards Adjacent Wall to avoid becoming an obstruction to usable room space or creating Dead Space on GLA) Consult with NICD Project Manager for Approval prior to procurement. NB: Provide Installation and Compliance Certificates for ALL Fire Doors Installed				
23	<p>Remove existing single door and replace with a suitable fixed uPVC double glazed uPVC Panel with properties as per item 8 above. Brick work should be until waist level or 1m from the floor level with the remainder until the ceiling being the viewing panel.</p> <p>Brick Wall Details:</p> <p>220x105x73mm NFP Clay or Cement Bricks, Inclusive of all ancillary requirements such as building and plaster mortar, brick force, damp-proof course, bonding agents and rhinolite</p> <p>Preparation:</p> <p>Prepare the floor/area for brick laying, ensure the floor/wall is clean, dust and laitance-free, level/plumb, pre-wetted and clear of any residue from previous flooring system installation. Where a new wall ties in with an existing brick wall, ensure adequate structural integrity of the new wall is achieved by either toothing or using Brick Wall Ties as per SANS 10400. Apply rhinolite where and old wall plaster is uneven to achieve a smooth finish. Ensure minimum thickness is achieved as per manufacture's recommendations to avoid premature flacking or delamination.</p> <p>Finishes:</p> <p>Prepaint: Apply 1 Coat Primer Undercoat: Apply 1 Coat White Waterbased Acrylic Sheen Top Coat: Apply 2 Coats White Waterbased Acrylic Sheen (Brilliant White)</p>	SUM	1		

24	<p>Supply and Install blinds on the viewing panel with following properties:</p> <p>Recessed Venetian Wooden Blinds</p> <p>Size: 50mm</p> <p>Design: Horizontal Slates</p> <p>Controls: Black Nylon String with matching plastic caps</p> <p>Thickness: TBA</p>	no	5		
25	<p>Supply and fit wall mounted floor to ceiling and wall to wall storage cabinets and shelves at ~300mm spacing. Units should be symmetric with aluminium skirting to prevent ingress of foreign objects under. Shelves should be adjustable at a range of 200mm to 500mm spacing to be done at the discretion of end user – ensure there are adequate holes and pins for such flexibility. Use white melamine board with suitable white PVC bevelled edging. 2 walls to have lockable cabinets with shelves and 2 walls to have shelves without doors.</p> <p>Where locks are installed, consider <i>Cam or Cabinet/Enclosure Locks</i>. Provide numbers to all cabinets/column units and labelled key tags that correspond to such numbers.</p>	No.	1		
26	<p>Provide COCs, Warranty and Guarantee Certificates for all installation i.e. Plumbing, Roofing, Glazing, Drainage and Electrical Installations.</p> <p>NB: Provide 3 Copies of Each as Original Documents for NICD Record Keeping</p>	SUM	ALL		
27	<p>Provide a Safety File with a list of all Artisan Competences (Qualifications and where applicable, Affiliations with relevant Regulatory bodies), Legal Appointments, Training and SOPs/Method Statements for the Various Trades. Include the Site Safety Management Plan (HSE Plan with relevant and full time 16.1; 16.2; 8.1; 8.2; and 8.6 Appointees) as contemplated in the Construction Regulations 2014 as well as a Schedule with Applicable Milestones, Critical Paths, Site Handover and</p>	SUM	1		

	<p>Official Project Close Outs or Completion Declaration, Proof of Material Delivery Agreements with respective Suppliers and Lead Times for Material Delivery. NICD Insists on a 2-year Warranty and Guarantee on ALL Installed items and workmanship.</p> <p>NB: Ensure that all the necessary safety aspects are observed as per the applicable regulations. PPE and access must be fit for purpose. Ensure that ALL Control measures are in place as required by the relevant DSTI/JHA and legislation.</p> <p>There will be a need to display or proof that these controls are in place at any given time as demanded by the NICD PM</p>				
28	Allow the amount of R 60 000-00 (Sixty Thousand Rand as Contingency to be used at the discretion of the Principal Agent and deducted in whole or in part if not required.	SUM	1		R60,000.00
	TOTAL				
	PLUS 15% VAT				
	GRAND TOTAL				
	Estimated time in Days to complete work above				

Administrative Mandatory Documents

No.	Mandatory Requirement	Comply	Not Comply
1	CSD FORM		
2	B-BBEE Certificate and/or Affidavit		
3	Tax Clearance Certificate and/or TAX Verification PIN		
4	Local Content (If applicable) 5.1 The bidder must complete and submit the SBD6.2 and Annexure C for Local Content If a bidder fails to meet, the minimum stipulated threshold for local production and content will be considered an unacceptable tender.	N/A	

Technical mandatory documents which should be included on submission

no	Certificate and or license	comply	Do not comply
1	Air conditioners trade test/competency certificate		
2	Electrical Wire man's license		
3	Bidder must provide details and registration confirmation with CIDB in terms of the CIDB Act 38 of 2000 (bidder must provide proof of 1GB ,1ME, 1SL,1EB & 1SO		
4	Working on heights competency certificate		
5	Bidder must provide a brochure to confirm the specification for all the product to be installed		
6	Plumbing Trade test/competency certificate		
7	Bidder must provide a sample of warranty certificate		

Important Note:

- Always read specification in conjunction with Bill of Quantities and Plan (if plan is applicable and supplied).
- All Quantities measured are indicative and will be re-measured on completion.
- Specific products to be used, to be confirmed in Bill of Quantities.
- All materials and products to be used, to be ISO 9001 accredited.
- Due to the nature of our labs (operation 24 hours) **the contractor will be expected to work after hours and over the weekend.**
- Variation orders can only be approved in writing (via the email) by the NHLS Project Manager
- No additional or extra work done will be paid for unless the project manager has issued a variation order.
- NHLS Project Manager will conduct all inspections.
- The contractor should be required to move the equipment (furniture, benches, etc.) and put them back requested.
- Only material installed will be paid and not for any wastage (no material on site will be paid).
- NHLS delegates can also and contact the client or visit the work done as referred on the completion certificate.
- Contractor will be requested to **provide comprehensive safety file**; work will be only allowed to commence after the file has been formally approve by NHLS.
- A contractor is expected to **sign a 37(2) Agreement** (Form – FMI 0008) before commencing with the project.
- **No progress payment will be made less than R200, 000.00.**

References:

- NHLS delegates can also and contact the client or visit the work done as referred on the reference or completion certificate.

If QUOTE VALUE	REQUIRED REFERENCE OR COMPLETION CERTIFICATES	CONTRACT VALUE OF PROJECT PREVIOUSLY DONE
R0- R50,000.00	One(1) copy of contactable reference or completion certificate, on client's letterhead, with contact details, valid e-mail address, office telephone, cell phone and business address	N/A
R50,000.00 - R100,000.00	Two(2) copies of contactable reference or completion certificate, , on client's letterhead, with contact details, valid e-mail address, office telephone, cell phone and business address	N/A
R100,000.00 - R200,000.00	Three(3) copies of contactable reference or completion certificate, , on client's letterhead, with contact details, valid e-mail address, office telephone, cell phone and business address	At least 1x R100,000.00 and above
R200,000.00 and above	Three(3) copies of contactable reference or completion certificate, , on client's letterhead, with contact details, valid e-mail address, office telephone, cell phone and business address	At least 3x R200,000.00 and above

- **All the contractors will be requested to provides NHLS with the following signed of stamped references or completion certificates of similar work done on company or departments letter head, not more than five years (5) old as per the table below**

3.1 Price Declaration Form

Please indicate your total RFQ price including vat here: _____ (compulsory)

Important:

It is mandatory to indicate your total RFQ price as requested above. This price must be the same as the total RFQ price you submit in your pricing schedule. Should the total RFQ prices differ, the one indicated above shall be considered the correct price.

The following must be noted:

- All prices must be VAT inclusive and must be quoted in South African Rand (ZAR).
- All prices must be firm and fixed from the tender closing date and for the duration of the contract
- All the consortium or joint venture partners must submit a complete set of the latest audited financial statements.
- All bidders must cost according to the costing template provided or this will lead to disqualification.
- The cost of delivery, labour etc. must be included in this proposal.
- Bidders must keep all items listed below in stock.

We undertake to hold this offer open for acceptance for a period of **60 days** from the date of submission of offers. We further undertake that upon final acceptance of our offer, we will commence with delivery when required to do so by the Client.

RFQ Number

Name of bidder

4 MANDATORY REQUIREMENTS

If a bidder does not comply fully with each of the mandatory requirements, it shall be regarded as mandatory non-performance/non-compliance and the proposal shall be disqualified. No “unanswered” questions will be allowed. If a response to a question has been indicated as comply but not elaborated upon or substantiated it shall be regarded as mandatory non- performance/non-compliance and the bid shall be disqualified. Bidders shall provide full and accurate answers to the mandatory questions posed in this document, and, where required, explicitly state either “Comply/Accept (with a “Yes”)” or “Do not comply/do not accept (with a “No”)” regarding compliance to the requirements. Bidders must substantiate their responses to all mandatory questions. PLEASE NOTE: If the response does not substantiate any of the points or requirements in the body of the tender, it will be deemed to not comply, even if the ‘Comply’ field has been marked. The supplier Please note will pay costs for evaluation studies in each laboratory: All documentation to substantiate the mandatory requirements has to be supplied

GUARANTEE, MAINTENANCE, PENALTY AND RETENTION PERIOD

The Guarantee and Maintenance period shall be for 12 months commencing on the date of Practical completion and acceptance of the Installation. During the Guarantee period the Contractor shall repair all defects in the Installation which may arise as a result of inferior quality materials or faulty workmanship. **5% retention of the contract price will be held back for a period of 3 months after date of Practical completion and acceptance of the installation**

The fact that the Installation will be used and occupied by the Employer during the guarantee period shall in no way exempt the Contractor from his responsibility under this clause

Should a non-urgent fault occur during the guarantee period the Contractor will be advised and he shall repair the fault in good time

Should a fault occur during the guarantee period, that is in the opinion of the Project Manager of an urgent nature, then the Contractor will be advised and shall proceed immediately to rectify the fault

Should a fault occur during the guarantee period, that is in the opinion of the Project Manager of an urgent nature, and the Contractor is not available, the Employer shall reserve the right to obtain the services of any available Contractor to repair the fault. The cost of such repair work shall be borne by the Contractor in accordance with the escalated rates. In such a case the faulty equipment shall be kept for scrutiny by the Contractor. If this occurs during the retention period and retention money is still due to the Contractor, such claim from the Alternative Contractor, will be deducted from the Retention fund

Should the frequency and breakdown/s, in the opinion of the Project Manager, become so regular as to constitute and unacceptable state of affairs or should the installation or portions thereof prove to be unacceptable, the Contractor shall upon receipt of a written instruction from the Project Manager, replace portions/components or even the entire installation if need be, at his own cost as prescribed by the Project Manager

Where the practical completion is not reached by the date stated in the Tender/ RFQ document or by the revised date granted by the Project Manager, the Contractor shall be liable to a Penalty deterrent by the Project Manager, which is in this instance .1% (point 1 percent) of the Tender/ RFQ Total value, Per Day

PRELIMINARIES

Tenderer's attention is drawn to the fact that the Hospital and Laboratory will be fully operational during the building process. The work will have to be carried out in phases and at times that must be liaised and agreed to with the Business Manager and Hospital Management. This might result in certain work being carried out at certain times only, even after hours of weekends. Also note that sensitive electronic equipment are in use and no work that cause a vibration can be carried out when these equipment are in operation. Operating theaters in the vicinity of the building work will also be in use during the building program and the Contractor must liaise closely with the Hospital Management and obtain their written consent and permission, before removing and/or servicing equipment/structures, that might interfere with the running of the theaters or any other service/s. The use of certain lifts for moving of material will also have to be agreed to with the Hospital Management. The tenderer must allow for this in his prices since no additional claim will be entertained in this regard

TENDERS SHOULD BE BASED ON THE FOLLOWING SPECIFICATIONS

SITE APPLICATION

Repair to cracks

Repairs to cracks 0.2^{mm} to 2^{mm}

Rake out with a scraped blade.

Remove dust and debris.

Fill with pure acrylic, paintable, flexible crack filler.

Cracks over 2^{mm}

Open out with a carborundum disk into a V shape minimum 3^{mm} wide.

Remove dust and debris.

Wet the crack and fill with damp 1:4 cement/sand mortar properly compacted into the cracks.

Repairs to Mortar Joints

Scrape out unsound mortar

Point solidly with 1:3 cement/sand mortar properly compacted into the joints

Repairs to Painted Wall Surface Coating

Remove loose paint with a sharp paint scraper or hand-held pneumatic engraving tools fitted with flat chisel heads

Feather edges of tightly bonded paint with a rough to medium grit paper

Built up paint covering flush with general surface area

Preparation - Generally

Materials used in preparation to be types recommended by their manufacturers and the coating manufacturer for the situation and surfaces being prepared.

Apply in strict accordance with the manufacturers specification.

Apply oil based stoppers/fillers after priming. Apply water based stoppers/fillers before priming unless recommended otherwise by manufacturer. Patch prime water based stoppers/fillers when applied after priming.

Ensure that doors and opening windows, etc, are "eased" as necessary before coating. Prime any resulting bare areas.

Plastered surfaces and fibre cement boards to be washed down and allowed to dry completely.

Unfinished concrete surfaces clean with 1:4 solution of spirit of salts: water.

All floors where painting is to be carried out to be swept clean, walls dusted down and unpainted surfaces protected.

Efflorescence

Remove surface salts and other loose material with a stiff brush or coarse dry cloth.

Leave for 48 hours and repeat process if further efflorescence occurs.

Sand glossy surfaces to provide a key for finish.

Ironmongery

Remove from surfaces to be coated and re-fit on completion. Do not remove hinges unless instructed to do so

Previously Uncoated Timber

Ensure that large and loose knots are removed and made good with sound timber of the same species. Sand down flush

Ensure that surfaces are clean and remove all oil, grease and excessive natural oils with suitable solvents

Sand to a smooth, even finish with arrises rounded or eased

Remove resinous bleeding by heat, apply two coats of knotting to resinous areas and all knots and allow to dry

Ensure that head of fasteners is countersunk sufficiently to hold stopping/filling. Fill nail and screw holes, joints, cracks, holes, depressions, open or coarse grain with matching coloured stopper/filler worked well in and finished off flush with surface. Sand smooth and remove dust

Sand down to remove all plaster stains pencil marks and other blemishes from timber that is to be oiled or stained

Previously Coated Timber

Strip any existing cracked or flaking varnish back to fresh wood

Sand down any discoloured areas to fresh wood

Ensure that surfaces are clean and remove all oil, grease and excessive natural oils with suitable solvents

Sound varnish to be sanded with 360 grit paper

Uncoated Masonry/Render

Remove dirt, surface deposits, loose and flaking material with a stiff brush

Fill holes and cracks flush with surface, rub down

Unpainted Plaster

Remove dirt and surface deposits with a stiff brush

Rub down to remove nibs, trowel marks and plaster splashes

Lightly rub over trowelled glossy plaster with worn abrasive paper

Fill depressions, holes and cracks and lightly rub down flush with surface

Steel Generally

Remove all loose and flaking paint

Feather edges of tightly bonding paint

Rusted Areas

Clean disk sand and wire brush to remove rust

Clean bare steel patches with a solvent wash

Rust convertor only to be used on small areas where hand cleaning is ineffective

Apply with a stiff brush ensuring penetration into any pitting

Inspect after two hours and recoat areas showing unconverted red rust

Prime surfaces as soon as possible after cleaning, and in any case within four hours

Coating

Painting Generally

Operatives must be appropriately skilled and experienced in the use of specified materials and methods of application

Do not use materials that show any brittleness when applied. Do not thin or intermix unless specified or recommended otherwise. If materials are found to have been thinned without authorization, the Project Manager may require an additional application of additional coats

Any priming as soon as possible on the same day as preparation is completed, ensure that coats are of adequate thickness and suit surface porosity

Adjacent coats of the same material must be of a different tint to ensure that each coat provides complete coverage

Apply coatings to clean, dust free, suitable dry surfaces in dry atmospheric conditions and after any previous coats have hardened. Lightly abrade between coats as necessary

Apply coatings evenly to give a smooth finish of uniform colour, free from brush marks, nibs, sags, runs and other defects. Cut in neatly and cleanly. Do not splash or mark adjacent surfaces

Keep all surfaces clean and free from dust during coating and drying. Adequately protect completed work from damage

Painted Joinery/woodwork

Before priming preservative treated timber, any cut surfaces to be retreated and all end grain to be liberally coated allowing it to soak in before recoating it

Pre-primed woodwork to be lightly rubbed down and patch prime to match existing
Prime: One coat primer, two coats to end grain which will be painted
Finish: Two coats Alkyd gloss, sanded down between coats

Staining

Check with stain manufacturer if primer is required for the species of timber and type of previously applied treatment.
Apply stain in flowing coats. Redistribute excess material by brushing before stain has set. Allow not less than 12 hours between coats

Varnishing

Thin first coat with white spirits according to manufacturer's recommendations
Brush well in avoiding aeration and lay off
Apply further coats of varnish, rubbing down lightly between coats along the grain

Bead Glazing to Coated Timber

Before Glazing: Apply first two coats to rebates and beads

Concealed Joinery Surfaces

Inaccessible parts of joinery constructions are to be primed and/or coated before assembly
Where one or more additional coats are specified to be applied, they must be applied to all surfaces, including those that will be concealed when incorporated into the building

Wooden Doors

Varnish or paint bottom edges before hanging

Completion

Ensure that opening lights/windows/hinges and other moving parts move freely. Remove all masking tape and temporary coverings afterwards

Protection

Adequately protect all surfaces that are not to be coated
Protect all surfaces from dust and damp
Where doors are delivered to site in a finished condition, provide all necessary protection to the doors when applying coatings to the frames

Air-conditioners

Contractor to provide adequate power supply to air con unit
12 month warrantee to be included
Contractor is liable for any damages to structure
All work must be SABS approved
Each air con to be separately wired via isolator from the DB board and connected with a circuit breaker (see size and Phase requirements as stipulated in Bill)
D/P Isolator to be installed and connected adjacent to air-con unit internally (see size and Phase requirements as stipulated in Bill)
Electrical Certificate Of Compliance to be issued on completion
Allow for drilling through wall and plaster/ patch and paint afterwards. Piping to installed through walls only, never glass panes
All piping/cabling to be in PVC trunking / ducting. Allow for correct lengths
Units always to be heating and cooling (unless otherwise stipulated in Bill)
All piping, brackets, gas up to commissioning to be included in pricing
Supply units of the following Manufacturers: Samsung, LG, Carrier, Daiken, York
All Air-cons to be Inverter type

Plumbing

Only registered Plumbers to be employed for any plumbing & drainage work

Allow for $\pm 2\text{m}^2$ tiling above each basin and sink

Allow for A Grade Glazed white tiles, 152 x 152mm, 5 – 6.5mm thick

Sinks size: 1350^{mm} x 535^{mm} unless otherwise specified in bill of quantities

Sink mixer for tea room sink to be 15mm chrome plated brass cobra mixer type tap

All basins to be white glazed, each fitted with an approved 32mm chrome plated brass waste fitting with screwed outlet, and a 15mm chrome plated brass elbow action tap connected to water supply

All sinks to be stand alone stainless steel sink, work area, splash back on Pre-manufactured 40 x 32^{mm} stainless steel square tubing frames, 4 legs on adjustable pedestals. Exposed surfaces having a smooth finish, each fitted with an approved 32mm chrome plated brass waste fitting with screwed outlet, and a 15mm chrome plated brass Hospital goose neck tap

Stainless steel grade 316 or Type 304 to be used for stainless steel sinks

All material to be SABS approved

Make sure all existing water pipes and waste is in good working condition

All existing basins and sinks to be washed and cleaned

On each water supply line, a ball valve need to be installed as close as possible to outlet, this includes basins, sinks, toilets

Each tap to be visibly marked with “H” or a “Red” mark for Hot water and “C” or a “Blue” mark for Cold water

Geysers: Install makes such as Franky, Kwikhot or similar. Install on a drip tray with drain pipe to outside, pressure valve, safety valve, shut off valve, overflow pipe. Isolator to be installed at least 1m from Geyser, hot and cold water supply lines to be bonded and earthed. Isolator to be wired to DB with dedicated double pole circuit breaker.

Toilets: these shall be deemed to include the following: WC Pan, flush valve or 11 litre cistern with flushing apparatus, float valve and flush pipe and all finishings to pipes and cistern. To be the wash down type, approximately 400 high manufactured of white glazed fireclay or vitreous china, each provided with the compatible “P” or “S” – Traps, jointed to Pan. Pans and traps to be set on and encased in Class B concrete not less than 100mm thick at any point or position

Wall mounted bowl urinals: to be of white glazed fireclay or vitreous china, approximately 700 x 380mm in size with back flush entry, secured to wall with at least 2 concealed hanger brackets. Each urinal to be fitted with 38mm chrome plated domical grating, urinal flushing valve complete with push button assembly, spreader and all other necessary chrome plated brass fittings as well as a chrome plated brass bottle trap

Hydroboil installations: Install always above sink (see bill of quantities for size)

Emergency shower: complete body shower with eye station. Flow rate to be 60 litre per minute. At floor level, 700mm below shower head, the radius of water reaching the floor should be 200mm. At the eye station flow rate should be 6 litre per minute at a flow pressure safe enough not to injure the User. This unit to be 1 metre from floor level. Make use of emergency showers as supplied by Broen, Bull Maurice Trading or similar

Electrical

Only registered Electricians to be employed for any electrical work

Wires to be used for sockets outlets; 2.5mm² PVC

Colour for 2- compartment steel/PVC power skirting unless differently specified in bill of quantities (colour to be confirmed)

Normal plugs to be white and dedicated plugs to be red

Electrician to consult with Lab Manager regarding lab equipment when circuit are installed to prevent overloading, new plug points to be wired from distribution board and marked properly

Legend card in DB to be up to date

Electrical Certificate of Completion to be issued on completion

All material to be SABS approved

All installations to comply with SANS10142 installation rules

All additional /replaced plugs, isolators and light switches must be labelled on the cover and Distribution Board

Circuit breakers to be SABS approved and type and size to be confirmed with Project Manager before installation
Hydroboils: wire from DB Board with 30Amp double pole isolator next to Unit (at least 1m away) and 20Amp circuit breaker in DB board

Shade ports

Item	Single	Double	Triple
Pitch Height	900	1350	1350
Clearance	2100	2100	2100
Width	3000	5000	7500
Length of span	5500	5500	5500
Cross	50 x 2	50 x 2	57 x 2
Cable	6mm galvanized in all cases		
Hoops	42 x 2	42 x 2	50 x 2
Cantilever (bottom)	50 x 2		
Cantilever (top arm)	42 x 2		
Cantilever (brace)	34 x 2		
Columns	165 x 3.5 x 4000		
Columns	50 x 2	76 x 2	76 x 2
Foundations	500 x 600 x 900		
Concrete	20 MPA for all		

The hanging braces must be braced

The hanging brace must have a 12.5 degree angle

The hoops must be rolled on a rolling machine and not cranked/ bend

Colour green

The cotton used for sewing the nets must be UV resistant

Workbenches & Tops

Worktops to be 32^{mm} thick, either 600mm, 900mm or 1200mm, Formica brand post form - white (unless otherwise stipulated in Bill)

Where necessary 75mm holes must be drilled in worktops to accommodate computer cables and power supply to machinery and be made good with a plastic grommet

Pre-manufacture 30^{mm} x 30^{mm} steel square tubing frames as supplied by SA Lab or similar, sections of 1 000mm wide and 500mm deep or 1000mm wide and 800mm deep, for post form tops. All 4 legs to be on lockable castors or adjustable inserts as per BOQ wheel diameter 100mm. Bench Units to be equipped with water, basins, sinks, to be on adjustable pedestals. Benches could be 730mm or 900mm high (see bill of quantities) Sections to be bolted together, not welded. All steelwork to be epoxy powder coated in dove grey colour.

Cupboards

steel laboratory cupboards

Steel epoxy powder coated white cupboards to be manufactured and assembled as follows. Units specified in bill will either be a 4 drawer (450mm wide) or 2 doors with 1 shelf unit (750mm wide). Exterior and Interior to be White powder coated. Doors to be affixed with 2 brass heavy duty piano hinges each and drawers to be mounted on runners. Each drawer and door to be equipped with a PVC recessed handle. All floor cupboards to be on 4 castors each, front wheels to be lockable. All doors to be double paneled for stability and no wobbly door and cupboards will be accepted. See bill of quantities for sizes and combinations.

wooden cupboards

In kitchens timber cupboards to be manufactured and installed with 16mm melamine covered pressed wood. All cupboards to be on 100mm pedestals. Exterior to be Oak finish and Interior to be white finish. All visible exterior edges to be finished in Oak and internally white. Each drawer faces and door to have wrap around finish. Doors to be affixed on 2 hinges each and drawers on runners. Each drawer and door to be equipped with an aluminium handle

Doors

All doors to be hung in such a way that the clearance gap between door and frame after hanging shall not exceed 2mm at sides and head. The floor clearance to be preferably 2mm but may be increased to accommodate an uneven floor finish. Exterior doors shall be hung on brass hinges. Aluminium frame glass doors to have 6mm safety laminated glass fitted, to be hung on aluminium hinges, not less than 4 hinges on a 2 100mm high door. On higher doors at least 5 hinges should be fitted. The glass door must have a mid-rail with bottom half either glass or solid aluminium, the aluminium door profile must be 90mm all-round All exterior doors to be fitted with an aluminium and rubber weather strip at the bottom. Each door to be equipped with 2 door handles. Type to be confirmed by Project Manager. Behind every door a door stop should be installed on top of the floor to prevent the door handle making contact with the wall – clearance between wall and door handle to be approximately 20mm.

Paint

Two final coats of White paint to all surfaces, ceiling and walls. Door colours to be confirmed by Project Manager, if not varnished

Existing pipes against wall must be colour coded painted, for example gas, water, oxygen

Rhino board surface to receive Rhinolite to a smooth finish on dry walls

Before painting can commence, every defect/uneven surface must be repaired

Patch prime new and exposed plaster areas with 1 coat and allow drying. Coat 1 may be thinned up to 10% with mineral turpentine to aid absorption. Allow 4 hours drying time at 23° c . Three (3) coats of paint to dry wall. Paint texture and type to match existing, Colour for walls and steel frames to be white unless otherwise confirmed by Project Manager

One coat metal primer to steel work and two coats final oil based enamel

Paint to be Plascon double velvet, Dulux, Prominent or similar

VINYL Floors

Only use Heavy duty safety Vinyl flooring which should be slip resistant and factory sealed with Polyurethane as supplied by Marley or Polyfloor. Roll to be at least 2 metres wide and vinyl 2 - 2.5 mm thick. Colour to be confirmed by Project Manager. Sample to be signed off by Project Manager before installation commences

Ensure that the sub-floor is completely smooth, level, hard, dry and clean before laying commences

Joints to be butted, grooved and heat welded ensuring that the welding rod bonds to more than 70% of the sheet thickness. It is essential that on completion the installation be rolled, in both directions with an articulated 68kg three sectional metal floor roller.

Skirting; install coving where wall meets floor and continue with vinyl floor 100mm high. Finish off with Vinyl/PVC Ribbon

Installation to be done by an approved Installer in accordance with the Manufacturers specifications

TILE Floors

Ensure that the sub-floor is completely smooth, level, hard, dry and clean before laying commences

Only use A Grade Acid resisting Ceramic/ porcelain tiles, 10mm thick, 600^{mm} x 600^{mm} for floors and 600^{mm} x 200^{mm} for walls in size or as per BOQ

All tiles need to have "Aluminium Tile Edge Trim" where necessary. Bull nose or square one may be used

Use SABS approved tile cement and apply as per Manufacturers instructions (colour to be confirmed by Project Manager)

Use SABS approved water proof Acid resistant grout. Gaps 5 – 10mm (colour grey)
Skirtings to be 100mm high where required, coved at junction with floor and rounded on top edge

CARPET Floors

Ensure that the sub-floor is completely smooth, level, hard, dry and clean before laying commences. Installation to be done by an approved Installer in accordance with the Manufacturer's specifications

TILE Walls

Ensure that the wall is completely smooth, level, hard, dry and clean before laying commences

Only use A Grade Acid resisting Ceramic tiles, 10mm thick, 600 x 200mm in size

Use SABS approved tile cement and apply as per Manufacturers instructions (colour to be confirmed by Project Manager)

All tiles need to have "Aluminium Tile Edge Trim" where necessary. Bull nose or square one may be used

Use SABS approved water proof Acid resistant grout. Gaps 5 – 10mm (colour grey)

All edges and corners to be finished off with PVC edging strips. Colour to be confirmed per job depending on tile colour.

Glazing

All Internal glass in panes not exceeding 1.5m² of surface area shall be 4mm clear float glass

All Internal glass in panes exceeding 1.5m² of surface area shall be 6mm laminated safety glass with a Manufacturer's warranty against defects and discoloration

All Exterior glass up to a height of 10m in panes not exceeding 2.9m² of surface area shall be 6.38mm PVB Laminated annealed safety glass. Above 10m the Project Manager should appoint a Glazing Competent Person

Mirrors to comply with SABS requirements. Unframed mirrors to have polished edges

All glass in aluminium doors and frames to be fitted with 6mm laminated safety glass

All exterior facing windows to be tinted with Klingshield or similar product, unless otherwise stipulated. Colour to be confirmed by Project Manager

Blinds

Vertical Group 3 blinds to be installed (colour to be confirmed by Project Manager)

Blinds to be re-measured on site before manufacturing and installation

Vertical blinds to be 127mm

Horizontal blinds 50mm

Horizontal blinds to be either Aluminium/ Wood Venetian conformation on the BOQ

Measurements given is only for tendering purpose

Suspended ceilings

Install suspended ceilings as per Manufacturers instructions such as Donn Products or similar. Panels to be vinyl clad smooth white panels, 1200 x 600 x 12.5mm on suspended pre-painted exposed tee trusses, including main and cross tees, hangers, grids, etc., all level and properly secured. At edges use 25mm pre-painted shadow line aluminium cornices

Partitioning

Drywall partitioning construction and support frame system including finishes to be as per Manufacturer's specifications

Minimum requirement GPG Gypsum Gyproe Standard 40 Db, ½ hour fire rating with a stud (63.5mm) and track system. Positioning at 600mm cc fixed to 63.5mm top & bottom track clad on both sides with 12.5mm taper edged rhino board affixed with 25mm drywall screws at 220mm cc

All corners to be finished off with drywall corner strips. All joints to be taped, jointed and smoothed before painting

Aluminium skirtings to be affixed to all drywall partitioning unless otherwise specified

Door and window frames fitted in drywall partitioning to be installed as per Manufacturer's specifications

Lockers (Timber)

Timber lockers to be manufactured and assembled with 16mm melamine covered pressed wood. Exterior to be Oak melamine finish, including all visible edges. Interior to be White melamine finish, including all visible edges and backing. If the back side of any cupboard will be visible after installation, those exposed areas or entire area should be clad with white melamine. Inside dimensions of each cubicle to be 300mm². Units to be assembled 3 on top of each other. Each locker to have a wrap around Oak melamine finished door, affixed with piano hinges. Each locker to be equipped with a lock and 2 keys as well as an aluminium handle (no plastic handles). Each stack of 3 to be assembled as 1 unit and 100mm adjustable chrome plated legs to be affixed underneath bottom locker.

Lab Coat Hooks

Lab coat hooks must be aluminium base and hooks with a minimum of three per set

Lockers (Steel)

Solid steel lockers which should be epoxy powder coated to be supplied. Sets to be single 4 tier lockers. Colour to Ivory/Beige/Karoo. Each door to be lockable and correct size padlocks with 2 keys each, per locker, to be provided

Locks

All exterior door locks to have 4 lever mortice locks with 2 keys each fitted (unless otherwise specified in bill)

All interior door locks to have 2 lever mortice locks with 2 keys each fitted (unless otherwise specified in bill)

All security type gates to have 7 lever locks with 2 keys each fitted

All timber lockers to have normal cupboard locks with 2 keys each fitted

All steel lockers to have padlocks with 2 keys each fitted

Steel shelving

Only powder coated grey steel shelving to be installed in storage areas, archives & wash up areas (no wood allowed). Shelving to be of an adjustable type with each shelf at least 500mm wide and 450mm deep. Bottom shelf to be at least 200mm from the floor and top shelf not higher than 2100mm. In between top and bottom another 3 shelves, evenly spaced, to be fitted (in total 5 tier shelving). Each vertical steel supports to be affixed to the wall at, at least 2 positions in the top half. As supplied by Krost shelving or similar

Signage

All interior signs to be White Perspex with smooth edges, with vinyl (7 year) applied onto the Perspex

All exterior signs to be White Chromadek, with vinyl (7 year) applied onto the metal

Colour code:

Pantone: Coated – 383C / Uncoated – 397 U

CMYK – C:40 M:0 Y:100 K0

RGB – R:166 G:206 B:54

Artwork to be signed off by Project Manager before sign is manufactured

PLEASE TAKE NOTE THAT THE ABOVE SPECIFICATIONS AND MEASUREMENTS ARE SUBJECT TO CHANGE AS MAY BE DETERMINED BY THE FINAL APPROVED DRAWINGS OR COMPULSARY SITE MEETING FOR THE JOB IN QUESTION

WORKS AGREEMENT

Contractor: The contractor shall:

- Provide adequate supervision and management of the works at all times.
- Provide toilet facilities for use by his workers except where provided by the client (NHLS).
- Storage space is not always available for material and sufficient arrangements should be catered for and included in pricing.
- Submit all local authority notices by the works.

- Comply with all statutes, regulations and bylaws of local or other authorities having jurisdiction regarding the execution of the works and obtain all certificates and other documents required by such authorities.
- Notify the Project Manager where compliance with any statute, regulation or bylaw requires a change or variation to the works upon which such change shall be deemed to be a contract instruction.
- Immediately begin the works and continue at a rate of progress satisfactory to the Project Manager in terms of the agreement.
- Comply with all contract instructions in good time.
- Bring the works, within the constructed period, to practical completion in terms of completion.
- Bring the works to final completion.
- Surplus material and waste to be carted away to a suitable dumping site to be found by the Contractor, outside the boundary of the site

Completion

Practical Completion

- The Project Manager shall inspect the works from time to time to give the contractor interpretations and guidance on the standard and state of completion of the works which he will require the contractor to achieve for practical completion
- The contractor shall inform the Project Manager of the date on which he expects to achieve practical completion
- The Project Manager shall inspect the works on or before the date requested by the contractor

Where the works:

- Has reached practical completion the Project Manager shall at once issue a certificate of practical completion to the contractor
- Has not reached practical completion the Project Manager shall issue a practical completion list to the contractor detailing the outstanding work to be done and defects to be rectified to achieve practical completion
- Is not ready for practical completion inspection the Project Manager shall issue a list as a general guide to the contractor of the outstanding areas of work and defects to be attended to before he can request a further inspection

Final Completion

- Within seven calendar days of practical completion the Project Manager shall prepare and issue to the contractor a final completion list detailing the incomplete work and defects to be rectified within a reasonable period
- The defects liability period of fourteen calendar days shall start on the date of practical completion
- On the expiry of the defects liability period the Project Manager shall immediately inspect the works for final completion. Where the works:
- Has reached final completion the Project Manager shall at once issue a certificate of final completion to the contractor
- Has not reached final completion the Project Manager shall issue a defects list to the contractor detailing any incomplete work and defects to be rectified before the Project Manager will undertake a further inspection
- Where the contractor has achieved final completion the latent defects liability period shall end three years from the date of final completion

Employer: The employer shall:

- Hand over the site to the contractor by the date stated in the schedule. The construction period and latent defects liability period shall commence with the handover of the site.
- Arrange for water, sewer and electrical connections as required and pay all fees concerning this
- Provide water and electricity as required for the execution of the works free of charge.
- Not issue instructions to, interfere with, hinder or obstruct any of the contractor's workers or any other persons employed or acting on behalf of the contractor.

Risk and Insurance

- The Contractor indemnifies the NHLS against any loss in respect of claims from other parties arising out of or due to the execution of the works or occupation of the site by the contractor consequent upon:

- Death or bodily injury or illness of any person.
 - Physical loss and damage to any property other than the works.
 - Removal of or interference with lateral support of an adjoining property.
- The contractor shall take out insurances in respect of his employees as are required by law.
 - Where, in the opinion of the Project Manager, loss and damage to the works due to the contractor's negligence the contractor shall be liable for such loss and damage.
 - The contractor shall in all circumstances be at risk for loss of, or damage to his construction plant or vehicles.
 - The contractor shall enclose the site along the facades where work is being done. He shall furthermore allow for all the required scaffolding, gantries, hoarding, etc. to safeguard pedestrian traffic on the sidewalks or paths as well as vehicular traffic in the streets
 - The form of scaffolding, gantries, hoardings, etc., must be fully detailed in his "method statement" as previously required. It is not the intention to prohibit or deviate pedestrians or traffic during construction and Tenderers are to account for this when pricing the Tender
 - Adequate warning signs/ lights/ etc. are to be employed where required. If the Tenderer requires the full pavement width and even part of the adjacent street, then he must make all the necessary arrangements with local authorities for the pavement and street closure as well as pay for all fees in connection therewith including the loss of income due to parking meters
 - The existing premises will be occupied at all times and the Contractor will be required to keep all noise to a minimum

Safety

- From the date of site handover to the Contractor until the completed work is handed back to the Employer, the Contractor shall be responsible for maintaining safe working conditions on site
- The Contractor shall be responsible in terms of the Occupational Health and Safety Act, 1993 (Act No 85 of 1993) and the regulations promulgated in terms of the Act or Factories, Machinery and Buildings Work Act, whichever is applicable
- The Contractor shall be responsible for supplying and installing the required safety signs as determined by the Occupational Health and Safety Act, 1993 (Act No 85 of 1993) All safety signs shall comply with the requirements of the latest edition of SANS 11861 as Applicable

Programme

- The Contractor shall submit his programme of work to the Project Manager not later than 14 days after the Contractor has been notified of the acceptance of his tender. If necessary, the Project Manager may instruct the Contractor to adjust his programme to suit other activities

END

5.PREFERENTIAL PROCUREMENT CLAIM FORM SBD 6.1

PREFERENCE POINTS CLAIM FORM IN TERMS OF THE PREFERENTIAL PROCUREMENT REGULATIONS 2011

•

This preference form must form part of all Bids invited. It contains general information and serves as a claim form for preference points for Broad-Based Black Economic Empowerment (B-BBEE) Status Level of Contribution

NB: Prior to completing this form, bidders must study the general conditions, definitions and directives applicable in respect of B-BBEE, as prescribed in the preferential procurement regulations, 2011.

GENERAL CONDITIONS

The following preference point systems are applicable to all Bids:

1.1 The following preference point systems are applicable to all bids:

1.1 The following preference point systems are applicable to all bids:

➤ the 80/20 system for requirements with a Rand value equal to above R30 000 and up to R50 million

➤ the 90/10 system for requirements with a Rand value above R50 million and above including taxes:

1.3 Preference points for this bid shall be awarded for:

- Price; and
- Specific contract participation goals, as specified in the attached forms.

1.5. The purchaser reserves the right to require of a bidder, either before a Bid is adjudicated or at any time subsequently, to substantiate any claim in regard to preferences, in any manner required by the purchaser.

2. Definitions

2.1 “all applicable taxes” includes value-added tax, pay as you earn, income tax, unemployment insurance fund contributions and skills development levies;

- 2.2 **“B-BBEE”** means broad-based black economic empowerment as defined in section 1 of the Broad-Based Black Economic Empowerment Act;
- 2.3 **“B-BBEE status level of contributor”** means the B-BBEE status received by a measured entity based on its overall performance using the relevant scorecard contained in the Codes of Good Practice on Black Economic Empowerment, issued in terms of section 9(1) of the Broad-Based Black Economic Empowerment Act;
- 2.4 **“bid”** means a written offer in a prescribed or stipulated form in response to an invitation by an organ of state for the provision of services, works or goods, through price quotations, advertised competitive bidding processes or proposals;
- 2.5 **“Broad-Based Black Economic Empowerment Act”** means the Broad-Based Black Economic Empowerment Act, 2003 (Act No. 53 of 2003);
- 2.6 **“comparative price”** means the price after the factors of a non-firm price and all unconditional discounts that can be utilised have been taken into consideration;
- 2.7 **“consortium or joint venture”** means an association of persons for the purpose of combining their expertise, property, capital, efforts, skill and knowledge in an activity for the execution of a contract;
- 2.8 **“contract”** means the agreement that results from the acceptance of a bid by an organ of state;
- 2.9 **“EME”** means any enterprise with annual total revenue of R5 million or less;
- 2.10 **“Firm price”** means the price that is only subject to adjustments in accordance with the actual increase or decrease resulting from the change, imposition, or abolition of customs or excise duty and any other duty, levy, or tax, which, in terms of the law or regulation, is binding on the contractor and demonstrably has an influence on the price of any supplies, or the rendering costs of any service, for the execution of the contract;
- 2.11 **“functionality”** means the measurement according to predetermined norms, as set out in the bid documents, of a service or commodity that is designed to be practical and useful, working or operating, taking into account, among other factors, the quality, reliability, viability and durability of a service and the technical capacity and ability of a bidder;
- 2.12 **“non-firm prices”** means all prices other than “firm” prices;
- 2.13 **“person”** includes a juristic person;
- 2.14 **“rand value”** means the total estimated value of a contract in South African currency, calculated at the time of bid invitations, and includes all applicable taxes and excise duties;

- 2.15 *“sub-contract” means the primary contractor’s assigning, leasing, making out work to, or employing, another person to support such primary contractor in the execution of part of a project in terms of the contract;*
- 2.16 *“total revenue” bears the same meaning assigned to this expression in the Codes of Good Practice on Black Economic Empowerment, issued in terms of section 9(1) of the Broad-Based Black Economic Empowerment Act and promulgated in the Government Gazette on 9 February 2007;*
- 2.17 *“trust” means the arrangement through which the property of one person is made over or bequeathed to a trustee to administer such property for the benefit of another person; and*
- 2.18 *“trustee” means any person, including the founder of a trust, to whom property is bequeathed in order for such property to be administered for the benefit of another person.*

3. **Adjudication using a point system**

- 3.1 A contract may be awarded to a bidder that did not score the highest points in accordance with Section 2(1)(f) of the PPPFA wherein a bid has been advertised with an objective criterion.
- 3.2 Preference points shall be calculated after prices have been brought to a comparative basis taking into account all factors of non-firm prices and all unconditional discounts;
- 3.3 Points scored must be rounded off to the nearest two (2) decimal places.
- 3.4 In the event that two or more Bids have scored equal total points, the successful bid must be the one scoring the highest number of preference points for B-BBEE.
- 3.5 However, when functionality is part of the evaluation process and two or more Bids have scored equal points including equal preference points for B-BBEE, the successful bid must be the one scoring the highest score for functionality.
- 3.6 Should two or more Bids be equal in all respects; the award shall be decided by the drawing of lots.
4. An EME /QSE that is regarded as a specialized enterprise is required to submit a sworn affidavit confirming their annual turnover/ budget/ gross receipt and level of percentage of black beneficiaries or a B-BBEE level verification certificate to claim points as prescribed by regulation 6 and 7 of the Preferential Procurement Regulations 2017.
4. Bidders who qualify as EMEs in terms of the B-BBEE Act must submit a certificate issued by an Accounting Officer as contemplated in the CCA or a Verification Agency accredited by SANAS or a Registered Auditor. Registered auditors do not need to meet the prerequisite for IRBA’s approval

for the purpose of conducting verification and issuing EMEs with B-BBEE Status Level Certificates.

- 4.1 Bidders other than EMEs must submit their original and valid B-BBEE status level verification certificate or a certified copy thereof, substantiating their B-BBEE rating issued by a Registered Auditor approved by IRBA or a Verification Agency accredited by SANAS.
- 4.2 A trust, consortium or joint venture, will qualify for points for their B-BBEE status level as a legal entity, provided that the entity submits their B-BBEE status level certificate.
- 4.3 A trust, consortium or joint venture will qualify for points for their B-BBEE status level as an unincorporated entity, provided that the entity submits their consolidated B-BBEE scorecard as if they were a group structure and that such a consolidated B-BBEE scorecard is prepared for every separate bid.
- 5. Tertiary institutions and public entities will be required to submit their B-BBEE status level certificates in terms of the specialised scorecard contained in the B-BBEE Codes of Good Practice.
- 5.1 A person will not be awarded points for B-BBEE status level if it is indicated in the bid documents that such a bidder intends sub-contracting more than 25% of the value of the contract to any other enterprise that does not qualify for at least the points that such a bidder qualifies for, unless the intended sub-contractor is an EME that has the capability and ability to execute the sub-contract
- 5.2 A person awarded a contract may not sub-contract more than 25% of the value of the contract to any other enterprise that does not have an equal or higher B-BBEE status level than the person concerned, unless the contract is sub-contracted to an EME that has the capability and ability to execute the sub-contract

6 **Bid declaration**

- 6.1 Bidders who claim points in respect of B-BBEE status level of contribution must complete the following:

7 **B-BBEE status level of contribution claimed in terms of paragraphs 1.3.1.2 and 5.1**

- 7.1 B-BBEE Status Level of Contribution: _____ = _____ (maximum of 20 points)

(Points claimed in respect of paragraph 7.1 must be in accordance with the table reflected in paragraph 5.1 and must be substantiated by means of a B-BBEE certificate issued by a Verification Agency accredited by SANAS or a Registered Auditor approved by IRBA or an Accounting Officer as contemplated in the CCA).

8 Sub-contracting (Refer to paragraphs 5.7 and 5.8 above)

8.1 Will any portion of the contract be sub-contracted? YES / NO (delete which is not applicable)

8.1.1 If yes, indicate:

8.1.1.1 what percentage of the contract will be subcontracted?

_____ %

8.1.1.2 the name of the sub-contractor?

8.1.1.3 the B-BBEE status level of the subcontractor?

8.1.1.4 whether the sub-contractor is an EME? YES / NO (delete which is not applicable)

9 Declaration with regard to company/firm

9.1 Name of company/firm _____

9.2 VAT registration number _____

9.3 Company registration number

9.4 Type of company/ firm

Partnership/Joint Venture / Consortium

One-person business/sole propriety

Close corporation

Company

(Pty) Limited

[Tick applicable box]

9.5 Describe principal business activities

9.6 Company classification

Manufacturer

Supplier

Professional service provider

Other service providers, e.g. transporter.

[Tick applicable box]

9.7 Total number of years the company/firm has been in business?

9.8 I/we, the undersigned, who is / are duly authorised to do so on behalf of the company/firm, certify that the points claimed, based on the B-BBE status level of contribution indicated in paragraph 7 of the foregoing certificate, qualifies the company/firm for the preference(s) shown and I / we acknowledge that:

9.8.1 The information furnished is true and correct;

9.8.2 The preference points claimed are in accordance with the General Conditions as indicated in paragraph 1 of this form.

9.8.3 In the event of a contract being awarded as a result of points claimed as shown in paragraph 7, the contractor may be required to furnish documentary proof to the satisfaction of the purchaser that the claims are correct;

9.8.4 If the B-BBEE status level of contribution has been claimed or obtained on a fraudulent basis or any of the conditions of contract have not been fulfilled, the purchaser may, in addition to any other remedy it may have –

9.8.4.1 disqualify the person from the bidding process;

9.8.4.2 recover costs, losses or damages it has incurred or suffered as a result of that person's conduct;

9.8.4.3 cancel the contract and claim any damages which it has suffered as a result of having to make less favourable arrangements due to such cancellation;

- restrict the bidder or contractor, its shareholders and directors, or only the shareholders and directors who acted on a fraudulent basis, from obtaining business from any organ of state for a period not exceeding ten (10) years, after the *audi alteram partem* (hear the other side) rule has been applied; and forward the matter for criminal prosecution.

Witnesses:

Signature(s) of bidder(s)

Date:

Address: _____

TAX CLEARANCE REQUIREMENTS SBD 2

- 1 It is a condition of Bid that the taxes of the successful bidder must be in order, or that satisfactory arrangements have been made with South African Revenue Service (SARS) to meet the bidder's tax obligations.
- 2 In order to meet this requirement bidder are required to complete in full the attached form TCC 001 "Application for a Tax Clearance Certificate" and submit it to any SARS branch office nationally. The tax clearance certificate requirements are also applicable to foreign bidders/individuals who wish to submit Bids.
- 3 SARS shall then furnish the bidder with a tax clearance certificate that shall be valid for a period of one (1) year from the date of approval.
- 4 The original tax clearance certificate must be submitted together with the Bid. Failure to submit the original and valid tax clearance certificate shall result in the invalidation of the Bid. Certified copies of the tax clearance certificate shall not be acceptable.
- 5 In Bids where Consortia / Joint Ventures / subcontractors are involved, each party must submit a separate tax clearance certificate.
- 6 Copies of the TCC 001 "Application for a Tax Clearance Certificate" form are available from any SARS branch office nationally or on the website www.sars.gov.za.
- 7 Applications for the tax clearance certificates may also be made via eFiling. In order to use this provision, taxpayers shall need to register with SARS as eFilers through the website www.sars.gov.za.

5.DECLARATION OF INTEREST SBD 4

BIDDER'S DISCLOSURE

1. PURPOSE OF THE FORM

Any person (natural or juristic) may make an offer or offers in terms of this invitation to bid. In line with the principles of transparency, accountability, impartiality, and ethics as enshrined in the Constitution of the Republic of South Africa and further expressed in various pieces of legislation, it is required for the bidder to make this declaration in respect of the details required hereunder.

Where a person/s are listed in the Register for Tender Defaulters and / or the List of Restricted Suppliers, that person will automatically be disqualified from the bid process.

2. Bidder's declaration

2.1 Is the bidder, or any of its directors / trustees / shareholders / members / partners or any person having a controlling interest¹ in the enterprise, employed by the state? **YES/NO**

2.1.1 If so, furnish particulars of the names, individual identity numbers, and, if applicable, state employee numbers of sole proprietor/ directors / trustees / shareholders / members/ partners or any person having a controlling interest in the enterprise, in table below.

Full Name	Identity Number	Name of institution	State

2.2 Do you, or any person connected with the bidder, have a relationship with any person who is employed by the procuring institution? **YES/NO**

2.2.1 If so, furnish particulars:

.....
.....

2.3 Does the bidder or any of its directors / trustees / shareholders / members / partners or any person having a controlling interest in the enterprise have any interest in any other

¹ the power, by one person or a group of persons holding the majority of the equity of an enterprise, alternatively, the person/s having the deciding vote or power to influence or to direct the course and decisions of the enterprise.

related enterprise whether or not they are bidding for this contract?

YES/NO

2.3.1 If so, furnish particulars:

.....
.....

3 DECLARATION

I, the undersigned, (name)..... in submitting the accompanying bid, do hereby make the following statements that I certify to be true and complete in every respect:

- 3.1 I have read and I understand the contents of this disclosure;
- 3.2 I understand that the accompanying bid will be disqualified if this disclosure is found not to be true and complete in every respect;
- 3.3 The bidder has arrived at the accompanying bid independently from, and without consultation, communication, agreement or arrangement with any competitor. However, communication between partners in a joint venture or consortium² will not be construed as collusive bidding.
- 3.4 In addition, there have been no consultations, communications, agreements or arrangements with any competitor regarding the quality, quantity, specifications, prices, including methods, factors or formulas used to calculate prices, market allocation, the intention or decision to submit or not to submit the bid, bidding with the intention not to win the bid and conditions or delivery particulars of the products or services to which this bid invitation relates.
- 3.4 The terms of the accompanying bid have not been, and will not be, disclosed by the bidder, directly or indirectly, to any competitor, prior to the date and time of the official bid opening or of the awarding of the contract.
- 3.5 There have been no consultations, communications, agreements or arrangements made by the bidder with any official of the procuring institution in relation to this procurement process prior to and during the bidding process except to provide clarification on the bid submitted where so required by the institution; and the bidder was not involved in the drafting of the specifications or terms of reference for this bid.
- 3.6 I am aware that, in addition and without prejudice to any other remedy provided to combat any restrictive practices related to bids and contracts, bids that are suspicious will be reported to the Competition Commission for investigation and possible imposition of administrative penalties in terms of section 59 of the Competition Act No 89 of 1998 and or may be reported to the National Prosecuting Authority (NPA) for criminal investigation and or may be restricted from conducting business with the public sector for a period not exceeding ten (10) years in terms of the Prevention and Combating of Corrupt Activities Act No 12 of 2004 or any other applicable legislation.

² Joint venture or Consortium means an association of persons for the purpose of combining their expertise, property, capital, efforts, skill and knowledge in an activity for the execution of a contract.

I CERTIFY THAT THE INFORMATION FURNISHED IN PARAGRAPHS 1, 2 and 3 ABOVE IS CORRECT.

I ACCEPT THAT THE STATE MAY REJECT THE BID OR ACT AGAINST ME IN TERMS OF PARAGRAPH 6 OF PFMA SCM INSTRUCTION 03 OF 2021/22 ON PREVENTING AND COMBATING ABUSE IN THE SUPPLY CHAIN MANAGEMENT SYSTEM SHOULD THIS DECLARATION PROVE TO BE FALSE.

.....
Signature Date

.....
Position Name of bidder

SCHEDULE 9: Declaration Certificate for Local Production and Content for Designated Sectors (SBD 6.2)

DECLARATION CERTIFICATE FOR LOCAL PRODUCTION AND CONTENT FOR DESIGNATED SECTORS

This Standard Bidding Document (SBD) must form part of all bids invited. It contains general information and serves as a declaration form for local content (local production and local content are used interchangeably).

Before completing this declaration, bidders must study the General Conditions, Definitions, Directives applicable in respect of Local Content as prescribed in the Preferential Procurement Regulations, 2017, the South African Bureau of Standards (SABS) approved technical specification number SATS 1286:2011 (Edition 1) and the Guidance on the Calculation of Local Content together with the Local Content Declaration Templates [Annex C (Local Content Declaration: Summary Schedule), D (Imported Content Declaration: Supporting Schedule to Annex C) and E (Local Content Declaration: Supporting Schedule to Annex C)].

1. General Conditions

- 1.1 Preferential Procurement Regulations, 2017 (Regulation 8) make provision for the promotion of local production and content.
- 1.2 Regulation 8. (2) prescribes that in the case of designated sectors, organs of state must advertise such tenders with the specific bidding condition that only locally produced or manufactured goods, with a stipulated minimum threshold for local production and content will be considered.
- 1.3 Where necessary, for tenders referred to in paragraph 1.2 above, a two stage bidding process may be followed, where the first stage involves a minimum threshold for local production and content and the second stage price and B-BBEE.
- 1.4 A person awarded a contract in relation to a designated sector, may not sub-contract in such a manner that the local production and content of the overall value of the contract is reduced to below the stipulated minimum threshold.
- 1.5 The local content (LC) expressed as a percentage of the bid price must be calculated in accordance with the SABS approved technical specification number SATS 1286: 2011 as follows:

$$LC = [1 - x / y] * 100$$

Where

x = is the imported content in Rand

y = is the bid price in Rand excluding value added tax (VAT)

Prices referred to in the determination of x must be converted to Rand (ZAR) by using the exchange rate published by South African Reserve Bank (SARB) on the date of advertisement of the bid as indicated in paragraph 3.1 below.

The SABS approved technical specification number SATS 1286:2011 is accessible on http://www.thedti.gov.za/industrial_development/ip.jsp at no cost.

1.6 A bid may be disqualified if this Declaration Certificate and the Annex C (Local Content Declaration: Summary Schedule) are not submitted as part of the bid documentation;

2. The stipulated minimum threshold(s) for local production and content (refer to Annex A of SATS 1286:2011) for this bid is/are as follows:

<u>Description of services, works or goods</u>	<u>Stipulated minimum threshold</u>
_____	_____ %
_____	_____ %
_____	_____ %

3. Does any portion of the goods or services offered have any

YES		NO	
-----	--	----	--

 imported content?

(Tick applicable box)

3.1 If yes, the rate(s) of exchange to be used in this bid to calculate the local content as prescribed in paragraph 1.5 of the general conditions must be the rate(s) published by SARB for the specific currency on the date of advertisement of the bid.

3.2 The relevant rates of exchange information is accessible on www.resbank.co.za.

3.3 Indicate the rate(s) of exchange against the appropriate currency in the table below (refer to Annex A of SATS 1286:2011):

Currency	Rates of exchange
US Dollar	
Pound Sterling	
Euro	
Yen	

Currency	Rates of exchange
Other	

NB: Bidders must submit proof of the SARB rate (s) of exchange used.

4. Where, after the award of a bid, challenges are experienced in meeting the stipulated minimum threshold for local content the dti must be informed accordingly in order for the dti to verify and in consultation with the AO/AA provide directives in this regard.

LOCAL CONTENT DECLARATION

(REFER TO ANNEX B OF SATS 1286:2011)

--

ANNEX C

Note: VAT to be excluded from all calculations

(C1) Tender No.:							
(C2) Tender description:							
(C3) Designated product(s):							
(C4) Tender Authority:							
(C5) Tendering Entity name:							
(C6) Tender Exchange Rate:	Pula		EU		GBP		
(C7) Specified local content %							

Tender item no's	List of items	Calculation of local content							Tender summary			
		Tender price - each (excl. VAT)	Exempted imported value	Tender value- net of exempted imported content	Imported value	Local value	Local content % (per item)		Tender Qty	Total tender value	Total exempted imported content	Total Imported content
(C8)	(C9)	(C10)	(C11)	(C12)	(C13)	(C14)	(C15)		(C16)	(C17)	(C18)	(C19)

Tender item no's	List of items	Calculation of local content						Tender summary			
		Tender price - each (excl. VAT)	Exempted imported value	Tender value- net of exempted imported content	Imported value	Local value	Local content % (per item)	Tender Qty	Total tender value	Total exempted imported content	Total Imported content
(C8)	(C9)	(C10)	(C11)	(C12)	(C13)	(C14)	(C15)	(C16)	(C17)	(C18)	(C19)
(C20) Total tender value									R0		
(C21) Total Exempt imported content										R0	
(C22) Total Tender value net of exempt imported content										R0	
(C23) Total Imported content											R0
(C24) Total local content											R0
(C25) Average local content % of tender											

Signature of tenderer from Annex B: _____

Tender item no's	List of items	Calculation of local content							Tender summary			
		Tender price - each (excl. VAT)	Exempted imported value	Tender value- net of exempted imported content	Imported value	Local value	Local content % (per item)		Tender Qty	Total tender value	Total exempted imported content	Total Imported content
(C8)	(C9)	(C10)	(C11)	(C12)	(C13)	(C14)	(C15)		(C16)	(C17)	(C18)	(C19)

Date: _____

DECLARATION OF BIDDER'S PAST SUPPLY CHAIN MANAGEMENT PRACTICES

- This Standard Bidding Document must form part of all Bids invited.
- It serves as a declaration to be used by institutions in ensuring that when goods and services are being procured, all reasonable steps are taken to combat the abuse of the supply chain management system.
- The Bid of any bidder may be disregarded if that bidder, or any of its directors have:
 - abused the institution's supply chain management system;
 - committed fraud or any other improper conduct in relation to such system; or
 - failed to perform on any previous contract.

In order to give effect to the above, the following questionnaire must be completed and submitted with the Bid.

Item	Question	Yes	No
4.1	<p>Is the bidder or any of its directors listed on the National Treasury's database as companies or persons prohibited from doing business with the public sector?</p> <p>(Companies or persons who are listed on this database were informed in writing of this restriction by the National Treasury after the <i>audi alteram partem</i> rule was applied).</p>	Yes	No
4.1.1	If so, furnish particulars:		
4.2	<p>Is the bidder or any of its directors listed on the Register for Tender Defaulters in terms of section 29 of the Prevention and Combating of Corrupt Activities Act (No 12 of 2004)?</p> <p>To access this Register enter the National Treasury's website, www.treasury.gov.za, click on the icon "Register for Tender Defaulters" or submit your written request for a hard copy of the Register to facsimile number (012) 3265445.</p>	Yes	No
4.2.1	If so, furnish particulars:		

4.3	Was the bidder or any of its directors convicted by a court of law (including a court outside of the RSA) for fraud or corruption during the past five years?	Yes	No
4.3.1	If so, furnish particulars:		
4.4	Was any contract between the bidder and any organ of State terminated during the past five years on account of failure to perform on or comply with the contract?	Yes	No
4.4.1	If so, furnish particulars:		

CERTIFICATION

I, the undersigned (full name) _____
certify that the information furnished on this declaration form is true and correct.

I accept that, in addition to cancellation of a contract, action may be taken against me should this declaration prove to be false.

Signature

Date

Position

Name of bidder

Js365bW

CERTIFICATE OF INDEPENDENT BID DETERMINATION SBD 9

This Standard Bidding Document (SBD) must form part of all Bids invited.

1. Section 4 (1) (b) (iii) of the Competition Act No. 89 of 1998, as amended, prohibits an agreement between, or concerted practice by, firms, or a decision by an association of firms, if it is between parties in a horizontal relationship and if it involves collusive bidding (or bid rigging). Collusive bidding is a *pe se* prohibition meaning that it cannot be justified under any grounds.
2. Treasury Regulation 16A9 prescribes that accounting officers and accounting authorities must take all reasonable steps to prevent abuse of the supply chain management system and authorises accounting officers and accounting authorities to:
 - 2.1 disregard the bid of any bidder if that bidder or any of its directors have abused the institution's supply chain management system and/or committed fraud or any other improper conduct in relation to such system.
 - 2.2 cancel a contract awarded to a supplier of goods and services if the supplier committed any corrupt or fraudulent act during the bidding process or the execution of that contract.
3. This SBD serves as a certificate of declaration that would be used by institutions to ensure that, when Bids are considered, reasonable steps are taken to prevent any form of bid rigging.
4. In order to give effect to the above, the attached Certificate of Bid Determination (SBD 9) must be completed and submitted with the bid:

I, the undersigned, in submitting the accompanying bid:

(Bid number and description)

in response to the invitation for the bid made by:

(Name of institution)

do hereby make the following statements that I certify to be true and complete in every respect:

I certify, on behalf of: _____ that:

(Name of bidder)

- I have read and I understand the contents of this certificate;
- I understand that the accompanying bid will be disqualified if this certificate is found not to be true and complete in every respect;
- I am authorised by the bidder to sign this certificate, and to submit the accompanying bid, on behalf of the bidder;
- Each person whose signature appears on the accompanying bid has been authorised by the bidder to determine the terms of, and to sign the bid, on behalf of the bidder;
- For the purposes of this certificate and the accompanying bid, I understand that the word “competitor” shall include any individual or organisation, other than the bidder, whether or not affiliated with the bidder, who:
 - 5.1 has been requested to submit a bid in response to this bid invitation;
 - 5.2 could potentially submit a bid in response to this bid invitation, based on their qualifications, abilities or experience; and
 - 5.3 provides the same goods and services as the bidder and/or is in the same line of business as the bidder.
- The bidder has arrived at the accompanying bid independently from, and without consultation, communication, agreement or arrangement with any competitor. However, communication between partners in a joint venture or consortium will not be construed as collusive bidding.
- In particular, without limiting the generality of paragraphs 6 above, there has been no consultation, communication, agreement or arrangement with any competitor regarding:
 - prices;
 - geographical area where product or service will be rendered (market allocation)
 - 6. methods, factors or formulas used to calculate prices;
 - 6.2 the intention or decision to submit or not to submit, a bid;
 - 6.3 the submission of a bid which does not meet the specifications and conditions of the bid; or
 - 7.1 bidding with the intention not to win the Bid.
- In addition, there have been no consultations, communications, agreements or arrangements with any competitor regarding the quality, quantity, specifications and conditions or delivery particulars of the products or services to which this bid invitation relates.

- The terms of the accompanying bid have not been, and will not be, disclosed by the bidder, directly or indirectly, to any competitor, prior to the date and time of the official bid opening or of the awarding of the contract.
- I am aware that, in addition and without prejudice to any other remedy provided to combat any restrictive practices related to Bids and contracts, Bids that are suspicious will be reported to the Competition Commission for investigation and possible imposition of administrative penalties in terms of section 59 of the Competition Act No 89 of 1998 and/or may be reported to the National Prosecuting Authority (NPA) for criminal investigation and/or may be restricted from conducting business with the public sector for a period not exceeding ten (10) years in terms of the Prevention and Combating of Corrupt Activities Act No 12 of 2004 or any other applicable legislation.

Signature

Date

Position

Name of bidder

Js914w 2

Government Procurement: General Conditions of Contract – July 2011

NOTES

The purpose of this document is to:

- (i) Draw special attention to certain general conditions applicable to government Bids, contracts and orders; and
- (ii) To ensure that clients be familiar with regard to the rights and obligations of all parties involved in doing business with government.

In this document words in the singular also mean in the plural and vice versa and words in the masculine also mean in the feminine and neuter.

☐ The GCC will form part of all bid documents and may not be amended.

☐ Special Conditions of Contract (SCC) relevant to a specific bid, should be compiled separately for every bid (if (applicable) and will supplement the GCC. Whenever there is a conflict, the provisions in the SCC shall prevail.

TABLE OF CLAUSES

1. Definitions
2. Application
3. General
4. Standards
5. Use of contract documents and information; inspection
6. Patent rights
7. Performance security
8. Inspections, tests and analysis
9. Packing
10. Delivery and documents
11. Insurance
12. Transportation
13. Incidental services
14. Spare parts
15. Warranty

16. Payment
17. Prices
18. Contract amendments
19. Assignment
20. Subcontracts
21. Delays in the supplier's performance
22. Penalties
23. Termination for default
24. Dumping and countervailing duties
25. Force Majeure
26. Termination for insolvency
27. Settlement of disputes
28. Limitation of liability
29. Governing language
30. Applicable law
31. Notices
32. Taxes and duties
33. National Industrial Participation Programme (NIPP)
34. Prohibition of restrictive practices

GENERAL CONDITIONS OF CONTRACT

1. Definitions

The following terms shall be interpreted as indicated:

- 1.1 "Closing time" means the date and hour specified in the bidding documents for the receipt of Bids.
- 1.2 "Contract" means the written agreement entered into between the purchaser and the supplier, as recorded in the contract form signed by the parties, including all attachments and appendices thereto and all documents incorporated by reference therein.
- 1.3 "Contract price" means the price payable to the supplier under the contract for the full and proper performance of his contractual obligations.

- 1.4 "Corrupt practice" means the offering, giving, receiving, or soliciting of anything of value to influence the action of a public official in the procurement process or in contract execution.
- 1.5 "Countervailing duties" are imposed in cases where an enterprise abroad is subsidized by its government and encouraged to market its products internationally.
- 1.6 "Country of origin" means the place where the goods were mined, grown or produced or from which the services are supplied. Goods are produced when, through manufacturing, processing or substantial and major assembly of components, a commercially recognized new product results that is substantially different in basic characteristics or in purpose or utility from its components.
- 1.7 "Day" means calendar day.
- 1.8 "Delivery" means delivery in compliance with the conditions of the contract or order.
- 1.9 "Delivery ex stock" means immediate delivery directly from stock actually on hand.
- 1.10 "Delivery into consignees store or to his site" means delivered and unloaded in the specified store or depot or on the specified site in compliance with the conditions of the contract or order, the supplier bearing all risks and charges involved until the supplies are so delivered and a valid receipt is obtained.
- 1.11 "Dumping" occurs when a private enterprise abroad market its goods on own initiative in the RSA at lower prices than that of the country of origin and which have the potential to harm the local industries in the RSA.
- 1.12 "Force majeure" means an event beyond the control of the supplier and not involving the supplier's fault or negligence and not foreseeable. Such events may include, but is not restricted to, acts of the purchaser in its sovereign capacity, wars or revolutions, fires, floods, epidemics, quarantine restrictions and freight embargoes.
- 1.13 "Fraudulent practice" means a misrepresentation of facts in order to influence a procurement process or the execution of a contract to the detriment of any bidder, and includes collusive practice among bidders (prior to or after bid submission) designed to establish bid prices at artificial non-competitive levels and to deprive the bidder of the benefits of free and open competition.
- 1.14 "GCC" means the General Conditions of Contract.
- 1.15 "Goods" means all of the equipment, machinery, and/or other materials that the supplier is required to supply to the purchaser under the contract.

- 1.16 “Imported content” means that portion of the bidding price represented by the cost of components, parts or materials which have been or are still to be imported (whether by the supplier or his subcontractors) and which costs are inclusive of the costs abroad, plus freight and other direct importation costs such as landing costs, dock dues, import duty, sales duty or other similar tax or duty at the South African place of entry as well as transportation and handling charges to the factory in the Republic where the supplies covered by the bid will be manufactured.
- 1.17 “Local content” means that portion of the bidding price which is not included in the imported content provided that local manufacture does take place.
- 1.18 “Manufacture” means the production of products in a factory using labour, materials, components and machinery and includes other related value-adding activities.
- 1.19 “Order” means an official written order issued for the supply of goods or works or the rendering of a service.
- 1.20 “Project site,” where applicable, means the place indicated in bidding documents.
- 1.21 “Purchaser” means the organisation purchasing the goods.
- 1.22 “Republic” means the RSA.
- 1.23 “SCC” means the Special Conditions of Contract.
- 1.24 “Services” means those functional services ancillary to the supply of the goods, such as transportation and any other incidental services, such as installation, commissioning, provision of technical assistance, training, catering, gardening, security, maintenance and other such obligations of the supplier covered under the contract.
- 1.25 “Written” or “in writing” means handwritten in ink or any form of electronic or mechanical writing.

2 Application

- 2.1 These general conditions are applicable to all Bids, contracts and orders including Bids for functional and professional services, sales, hiring, letting and the granting or acquiring of rights, but excluding immovable property, unless otherwise indicated in the bidding documents.
- 2.2 Where applicable, SCC are also laid down to cover specific supplies, services or works.
- 2.3 Where such SCC are in conflict with these general conditions, the special conditions shall apply.

3 General

3.1 Unless otherwise indicated in the bidding documents, the purchaser shall not be liable for any expense incurred in the preparation and submission of a bid. Where applicable a non-refundable fee for documents may be charged.

3.2 With certain exceptions, invitations to bid are only published in the Government Tender Bulletin. The Government Tender Bulletin may be obtained directly from the Government Printer, Private Bag X85, Pretoria 0001, or accessed electronically from www.treasury.gov.za

4 **Standards-**

4.1 The goods supplied shall conform to the standards mentioned in the bidding documents and specifications.

- **Use of contract documents and information; inspection**

5.1 The supplier shall not, without the purchaser's prior written consent, disclose the contract, or any provision thereof, or any specification, plan, drawing, pattern, sample, or information furnished by or on behalf of the purchaser in connection therewith, to any person other than a person employed by the supplier in the performance of the contract. Disclosure to any such employed person shall be made in confidence and shall extend only so far as may be necessary for purposes of such performance.

5.2 The supplier shall not, without the purchaser's prior written consent, make use of any document or information mentioned in GCC clause 5.1 except for purposes of performing the contract.

5.3 Any document, other than the contract itself mentioned in GCC clause 5.1 shall remain the property of the purchaser and shall be returned (all copies) to the purchaser on completion of the supplier's performance under the contract if so required by the purchaser.

5.4 The supplier shall permit the purchaser to inspect the supplier's records relating to the performance of the supplier and to have them audited by auditors appointed by the purchaser, if so required by the purchaser.

6 **Patent rights**

6.1 The supplier shall indemnify the purchaser against all third-party claims of infringement of patent, trademark, or industrial design rights arising from use of the goods or any part thereof by the purchaser.

Performance security

7.1 Within thirty (30) days of receipt of the notification of contract award, the successful bidder shall furnish to the purchaser the performance security of the amount specified in SCC.

- 7.2 The proceeds of the performance security shall be payable to the purchaser as compensation for any loss resulting from the supplier's failure to complete his obligations under the contract.
- 7.3 The performance security shall be denominated in the currency of the contract, or in a freely convertible currency acceptable to the purchaser and shall be in one of the following forms:
- 7.3.1 a bank guarantee or an irrevocable letter of credit issued by a reputable bank located in the purchaser's country or abroad, acceptable to the purchaser, in the form provided in the bidding documents or another form acceptable to the purchaser; or
- 7.3.2 a cashier's or certified cheque
- 7.4 The performance security will be discharged by the purchaser and returned to the supplier not later than thirty (30) days following the date of completion of the supplier's performance obligations under the contract, including any warranty obligations, unless otherwise specified in SCC.
- 8. Inspections, tests and analyses**
- 8.1 All pre-bidding testing will be for the account of the bidder.
- 8.2 If it is a bid condition that supplies to be produced or services to be rendered should at any stage during production or execution or on completion be subject to inspection, the premises of the bidder or contractor shall be open, at all reasonable hours, for inspection by a representative of the Department or an organisation acting on behalf of the Department.
- 8.3 If there are no inspection requirements indicated in the bidding documents and no mention is made in the contract, but during the contract period it is decided that inspections shall be carried out, the purchaser shall itself make the necessary arrangements, including payment arrangements with the testing authority concerned.
- 8.4 If the inspections, tests and analyses referred to in clauses 8.2 and 8.3 show the supplies to be in accordance with the contract requirements, the cost of the inspections, tests and analyses shall be defrayed by the purchaser.
- 8.5 Where the supplies or services referred to in clauses 8.2 and 8.3 do not comply with the contract requirements, irrespective of whether such supplies or services are accepted or not, the cost in connection with these inspections, tests or analyses shall be defrayed by the supplier.
- 8.6 Supplies and services which are referred to in clauses 8.2 and 8.3 and which do not comply with the contract requirements may be rejected.

8.7 Any contract supplies may on or after delivery be inspected, tested or analysed and may be rejected if found not to comply with the requirements of the contract. Such rejected supplies shall be held at the cost and risk of the supplier who shall, when called upon, remove them immediately at his own cost and forthwith substitute them with supplies which do comply with the requirements of the contract. Failing such removal, the rejected supplies shall be returned at the suppliers cost and risk. Should the supplier fail to provide the substitute supplies forthwith, the purchaser may, without giving the supplier further opportunity to substitute the rejected supplies, purchase such supplies as may be necessary at the expense of the supplier.

8.8 The provisions of clauses 8.4 to 8.7 shall not prejudice the right of the purchaser to cancel the contract on account of a breach of the conditions thereof, or to act in terms of Clause 23 of GCC.

9 **Packing**

9.1 The supplier shall provide such packing of the goods as is required to prevent their damage or deterioration during transit to their final destination, as indicated in the contract. The packing shall be sufficient to withstand, without limitation, rough handling during transit and exposure to extreme temperatures, salt and precipitation during transit, and open storage. Packing, case size and weights shall take into consideration, where appropriate, the remoteness of the goods' final destination and the absence of heavy handling facilities at all points in transit.

9.2 The packing, marking, and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the contract, including additional requirements, if any, specified in SCC, and in any subsequent instructions ordered by the purchaser.

10 **Delivery and documents**

10.1 Delivery of the goods shall be made by the supplier in accordance with the terms specified in the contract. The details of shipping and/or other documents to be furnished by the supplier are specified in SCC.

10.2 Documents to be submitted by the supplier are specified in SCC.

11 **Insurance**

11.1 The goods supplied under the contract shall be fully insured in a freely convertible currency against loss or damage incidental to manufacture or acquisition, transportation, storage and delivery in the manner specified in the SCC.

12 Transportation

- 12.1 Should a price other than an all-inclusive delivered price be required, this shall be specified in the SCC.

13 Incidental services

- 13.1 The supplier may be required to provide any or all of the following services, including additional services, if any, specified in SCC:
- 13.1.1 performance or supervision of on-site assembly and/or commissioning of the supplied goods;
 - 13.1.2 furnishing of tools required for assembly and/or maintenance of the supplied goods;
 - 13.1.3 furnishing of a detailed operations and maintenance manual for each appropriate unit of the supplied goods;
 - 13.1.4 performance or supervision or maintenance and/or repair of the supplied goods, for a period of time agreed by the parties, provided that this service shall not relieve the supplier of any warranty obligations under this contract; and
 - 13.1.5 training of the purchaser's personnel, at the supplier's plant and/or on-site, in assembly, start-up, operation, maintenance, and/or repair of the supplied goods.
- 13.2 Prices charged by the supplier for incidental services, if not included in the contract price for the goods, shall be agreed upon in advance by the parties and shall not exceed the prevailing rates charged to other parties by the supplier for similar services.

14 Spare parts

- 14.1 As specified in SCC, the supplier may be required to provide any or all of the following materials, notifications, and information pertaining to spare parts manufactured or distributed by the supplier:
- 14.1.1 such spare parts as the purchaser may elect to purchase from the supplier, provided that this election shall not relieve the supplier of any warranty obligations under the contract; and
 - 14.1.2 in the event of termination of production of the spare parts:
 - 14.1.2.1 Advance notification to the purchaser of the pending termination, in sufficient time to permit the purchaser to procure needed requirements; and
 - 14.1.2.2 following such termination, furnishing at no cost to the purchaser, the blueprints, drawings, and specifications of the spare parts, if requested.

15 Warranty

- 15.1 The supplier warrants that the goods supplied under the contract are new, unused, of the most recent or current models, and that they incorporate all recent improvements in design and materials unless provided otherwise in the contract. The supplier further warrants that all goods supplied under this contract shall have no defect, arising from design, materials, or workmanship (except when the design and/or material is required by the purchaser's specifications) or from any act or omission of the supplier, that may develop under normal use of the supplied goods in the conditions prevailing in the country of final destination.
- 15.2 This warranty shall remain valid for twelve (12) months after the goods, or any portion thereof as the case may be, have been delivered to and accepted at the final destination indicated in the contract, or for eighteen (18) months after the date of shipment from the port or place of loading in the source country, whichever period concludes earlier, unless specified otherwise in SCC.
- 15.3 The purchaser shall promptly notify the supplier in writing of any claims arising under this warranty.
- 15.4 Upon receipt of such notice, the supplier shall, within the period specified in SCC and with all reasonable speed, repair or replace the defective goods or parts thereof, without costs to the purchaser.
- 15.5 If the supplier, having been notified, fails to remedy the defect(s) within the period specified in SCC, the purchaser may proceed to take such remedial action as may be necessary, at the supplier's risk and expense and without prejudice to any other rights which the purchaser may have against the supplier under the contract.

16 Payment

- 16.1 The method and conditions of payment to be made to the supplier under this contract shall be specified in SCC.
- 16.2 The supplier shall furnish the purchaser with an invoice accompanied by a copy of the delivery note and upon fulfilment of other obligations stipulated in the contract.
- 16.3 Payments shall be made promptly by the purchaser, but in no case later than thirty (30) days after submission of an invoice or claim by the supplier.
- 16.4 Payment will be made in rand unless otherwise stipulated in SCC.

17 Prices

- 17.1 Prices charged by the supplier for goods delivered and services performed under the contract shall not vary from the prices quoted by the supplier in his bid, with the exception of any price adjustments authorised in SCC or in the purchaser's request for bid validity extension, as the case may be.

18 Contract amendments

- 18.1 No variation in or modification of the terms of the contract shall be made except by written amendment signed by the parties concerned.

19 Assignment

- 19.1 The supplier shall not assign, in whole or in part, its obligations to perform under the contract, except with the purchaser's prior written consent.

20 Subcontracts

- 20.1 The supplier shall notify the purchaser in writing of all subcontracts awarded under this contract if not already specified in the bid. Such notification, in the original bid or later, shall not relieve the supplier from any liability or obligation under the contract.

21 Delays in the supplier's performance

- 21.1 Delivery of the goods and performance of services shall be made by the supplier in accordance with the time schedule prescribed by the purchaser in the contract.
- 21.2 If at any time during performance of the contract, the supplier or its subcontractor(s) should encounter conditions impeding timely delivery of the goods and performance of services, the supplier shall promptly notify the purchaser in writing of the fact of the delay, its likely duration and its cause(s). As soon as practicable after receipt of the supplier's notice, the purchaser shall evaluate the situation and may at his discretion extend the supplier's time for performance, with or without the imposition of penalties, in which case the extension shall be ratified by the parties by amendment of contract.
- 21.3 No provision in a contract shall be deemed to prohibit the obtaining of supplies or services from a national department, provincial department, or a local authority.
- 21.4 The right is reserved to procure outside of the contract small quantities or to have minor essential services executed if an emergency arises, the supplier's point of supply is not situated at or near the place where the supplies are required, or the supplier's services are not readily available.

21.5 Except as provided under GCC Clause 25, a delay by the supplier in the performance of its delivery obligations shall render the supplier liable to the imposition of penalties, pursuant to GCC Clause 22, unless an extension of time is agreed upon pursuant to GCC Clause 21.2 without the application of penalties.

21.6 Upon any delay beyond the delivery period in the case of a supplies contract, the purchaser shall, without cancelling the contract, be entitled to purchase supplies of a similar quality and up to the same quantity in substitution of the goods not supplied in conformity with the contract and to return any goods delivered later at the supplier's expense and risk, or to cancel the contract and buy such goods as may be required to complete the contract and without prejudice to his other rights, be entitled to claim damages from the supplier.

22 Penalties

22.1 Subject to GCC Clause 25, if the supplier fails to deliver any or all of the goods or to perform the services within the period(s) specified in the contract, the purchaser shall, without prejudice to its other remedies under the contract, deduct from the contract price, as a penalty, a sum calculated on the delivered price of the delayed goods or unperformed services using the current prime interest rate calculated for each day of the delay until actual delivery or performance. The purchaser may also consider termination of the contract pursuant to GCC Clause 23.

23 Termination for default

23.1 The purchaser, without prejudice to any other remedy for breach of contract, by written notice of default sent to the supplier, may terminate this contract in whole or in part:

23.1.1 if the supplier fails to deliver any or all of the goods within the period(s) specified in the contract, or within any extension thereof granted by the purchaser pursuant to GCC Clause 21.2;

23.1.2 if the Supplier fails to perform any other obligation(s) under the contract; or

23.1.3 if the supplier, in the judgment of the purchaser, has engaged in corrupt or fraudulent practices in competing for or in executing the contract.

23.2 In the event the purchaser terminates the contract in whole or in part, the purchaser may procure, upon such terms and in such manner as it deems appropriate, goods, works or services similar to those undelivered, and the supplier shall be liable to the purchaser for any excess

costs for such similar goods, works or services. However, the supplier shall continue performance of the contract to the extent not terminated.

- 23.3 Where the purchaser terminates the contract in whole or in part, the purchaser may decide to impose a restriction penalty on the supplier by prohibiting such supplier from doing business with the public sector for a period not exceeding 10 years.
- 23.4 If a purchaser intends imposing a restriction on a supplier or any person associated with the supplier, the supplier will be allowed a time period of not more than fourteen (14) days to provide reasons why the envisaged restriction should not be imposed. Should the supplier fail to respond within the stipulated fourteen (14) days the purchaser may regard the intended penalty as not objected against and may impose it on the supplier.
- 23.5 Any restriction imposed on any person by the Accounting Officer / Authority will, at the discretion of the Accounting Officer / Authority, also be applicable to any other enterprise or any partner, manager, director or other person who wholly or partly exercises or exercised or may exercise control over the enterprise of the first-mentioned person, and with which enterprise or person the first-mentioned person, is or was in the opinion of the Accounting Officer / Authority actively associated.
- 23.6 If a restriction is imposed, the purchaser must, within five (5) working days of such imposition, furnish the National Treasury, with the following information:
- 23.6.1 the name and address of the supplier and / or person restricted by the purchaser;
- 23.6.2 the date of commencement of the restriction
- 23.6.3 the period of restriction; and
- 23.6.4 the reasons for the restriction.
- 23.7 These details will be loaded in the National Treasury's central database of suppliers or persons prohibited from doing business with the public sector.
- 23.8 If a court of law convicts a person of an offence as contemplated in sections 12 or 13 of the Prevention and Combating of Corrupt Activities Act, No. 12 of 2004, the court may also rule that such person's name be endorsed on the Register for Tender Defaulters. When a person's name has been endorsed on the Register, the person will be prohibited from doing business with the public sector for a period not less than five years and not more than 10 years. The National Treasury is empowered to determine the period of restriction and each case will be

dealt with on its own merits. According to section 32 of the Act the Register must be open to the public. The Register can be perused on the National Treasury website.

24 Anti-dumping and countervailing duties and rights

24.1 When, after the date of bid, provisional payments are required, or anti-dumping or countervailing duties are imposed, or the amount of a provisional payment or anti-dumping or countervailing right is increased in respect of any dumped or subsidized import, the State is not liable for any amount so required or imposed, or for the amount of any such increase. When, after the said date, such a provisional payment is no longer required or any such anti-dumping or countervailing right is abolished, or where the amount of such provisional payment or any such right is reduced, any such favourable difference shall on demand be paid forthwith by the contractor to the State or the State may deduct such amounts from moneys (if any) which may otherwise be due to the contractor in regard to supplies or services which he delivered or rendered, or is to deliver or render in terms of the contract or any other contract or any other amount which may be due to him.

25 Force majeure

25.1 Notwithstanding the provisions of GCC Clauses 22 and 23, the supplier shall not be liable for forfeiture of its performance security, damages, or termination for default if and to the extent that his delay in performance or other failure to perform his obligations under the contract is the result of an event of force majeure.

25.2 If a force majeure situation arises, the supplier shall promptly notify the purchaser in writing of such condition and the cause thereof. Unless otherwise directed by the purchaser in writing, the supplier shall continue to perform its obligations under the contract as far as is reasonably practical, and shall seek all reasonable alternative means for performance not prevented by the force majeure event.

26 Termination for insolvency

26.1 The purchaser may at any time terminate the contract by giving written notice to the supplier if the supplier becomes bankrupt or otherwise insolvent. In this event, termination will be without compensation to the supplier, provided that such termination will not prejudice or affect any right of action or remedy which has accrued or will accrue thereafter to the purchaser.

27 Settlement of disputes

- 27.1 If any dispute or difference of any kind whatsoever arises between the purchaser and the supplier in connection with or arising out of the contract, the parties shall make every effort to resolve amicably such dispute or difference by mutual consultation.
- 27.2 If, after thirty (30) days, the parties have failed to resolve their dispute or difference by such mutual consultation, then either the purchaser or the supplier may give notice to the other party of his intention to commence with mediation. No mediation in respect of this matter may be commenced unless such notice is given to the other party.
- 27.3 Should it not be possible to settle a dispute by means of mediation, it may be settled in a South African court of law.
- 27.4 Mediation proceedings shall be conducted in accordance with the rules of procedure specified in the SCC.
- 27.5 Notwithstanding any reference to mediation and/or court proceedings herein,
- 27.5.1 the parties shall continue to perform their respective obligations under the contract unless they otherwise agree; and
- 27.5.2 the purchaser shall pay the supplier any monies due the supplier.

28 Limitation of liability

- 28.1 Except in cases of criminal negligence or wilful misconduct, and in the case of infringement pursuant to Clause 6;
- 28.1.1 the supplier shall not be liable to the purchaser, whether in contract, tort, or otherwise, for any indirect or consequential loss or damage, loss of use, loss of production, or loss of profits or interest costs, provided that this exclusion shall not apply to any obligation of the supplier to pay penalties and/or damages to the purchaser; and
- 28.1.2 the aggregate liability of the supplier to the purchaser, whether under the contract, in tort or otherwise, shall not exceed the total contract price, provided that this limitation shall not apply to the cost of repairing or replacing defective equipment.

29 Governing language

- 29.1 The contract shall be written in English. All correspondence and other documents pertaining to the contract that is exchanged by the parties shall also be written in English.

30 Applicable law

30.1 The contract shall be interpreted in accordance with South African laws, unless otherwise specified in SCC.

31 Notices

31.1 Every written acceptance of a bid shall be posted to the supplier concerned by registered or certified mail and any other notice to him shall be posted by ordinary mail to the address furnished in his bid or to the address notified later by him in writing and such posting shall be deemed to be proper service of such notice

31.2 The time mentioned in the contract documents for performing any act after such aforesaid notice has been given, shall be reckoned from the date of posting of such notice.

32 Taxes and duties

32.1 A foreign supplier shall be entirely responsible for all taxes, stamp duties, license fees, and other such levies imposed outside the purchaser's country.

32.2 A local supplier shall be entirely responsible for all taxes, duties, license fees, etc., incurred until delivery of the contracted goods to the purchaser.

32.3 No contract shall be concluded with any bidder whose tax matters are not in order. Prior to the award of a bid the Department must be in possession of a tax clearance certificate, submitted by the bidder. This certificate must be an original issued by the SARSs.

33 National Industrial Participation (NIP) Programme

33.1 The NIP Programme administered by the DTI shall be applicable to all contracts that are subject to the NIP obligation.

34 Prohibition of restrictive practices

34.1 In terms of section 4 (1) (b) (iii) of the Competition Act No. 89 of 1998, as amended, an agreement between, or concerted practice by, firms, or a decision by an association of firms, is prohibited if it is between parties in a horizontal relationship and if a bidder (s) is / are or a contractor(s) was / were involved in collusive bidding (or bid rigging).

34.2 If a bidder(s) or contractor(s), based on reasonable grounds or evidence obtained by the purchaser, has / have engaged in the restrictive practice referred to above, the purchaser may refer the matter to the Competition Commission for investigation and possible imposition of administrative penalties as contemplated in the Competition Act No. 89 of 1998.

34.3 If a bidder(s) or contractor(s), has / have been found guilty by the Competition Commission of the restrictive practice referred to above, the purchaser may, in addition and without prejudice to any other remedy provided for, invalidate the bid(s) for such item(s) offered, and / or terminate the contract in whole or part, and / or restrict the bidder(s) or contractor(s) from conducting business with the public sector for a period not exceeding ten (10) years and / or claim damages from the bidder(s) or contractor(s) concerned.

The above General Conditions of Contract (GCC) are accepted by:

Name:	
Designation:	-
Bidder:	
Signature:	
Date:	

RFQ FOR THE SUPPLY/PROVISION OF

.....

FOR A PERIOD OF

**Section 5: CERTIFICATE OF ACQUAINTANCE WITH RFQ, TERMS & CONDITIONS & APPLICABLE
DOCUMENTS**

By signing this certificate, the Respondent is deemed to acknowledge that he/she has made himself/herself thoroughly familiar with, and agrees with all the conditions governing this RFP. This includes those terms and conditions contained in any printed form stated to form part hereof, including but not limited to the documents stated below. As such, NHLS will recognise no claim for relief based on an allegation that the Respondent overlooked any such condition or failed properly to take it into account for the purpose of calculating tendered prices or any other purpose:

1	NHLS' General Bid Conditions*
2	NHLS' Terms and Conditions of Contract for the supply of Services to NHLS

Should the Bidder find any terms or conditions stipulated in any of the relevant documents quoted in the RFQ unacceptable, it should indicate which conditions are unacceptable and offer alternatives by written submission on its company letterhead, attached to its submitted Bid. Any such submission shall be subject to review by NHLS' Legal Counsel who shall determine whether the proposed alternative(s) are acceptable or otherwise, as the case may be. A material deviation from any term or condition may result in disqualification.

Bidders accept that an obligation rests on them to clarify any uncertainties regarding any bid which they intend to respond on, before submitting the bid. The Bidder agrees that he/she will have no claim based on an allegation that any aspect of this RFQ was unclear but in respect of which he/she failed to obtain clarity.

The bidder understands that his/her Bid will be disqualified if the Certificate of Acquaintance with RFQ documents included in the RFQ as a returnable document, is found not to be true and complete in every respect.