

POCT Site I.T Specifications – UPS


R#: 1948663

1. 15U Network cabinet (Must Supply Brochure)
2. Cat6 Network Points, 3m Flyleads, 1.2m patch leads (Molex)
3. 3/2 KVA UPS, specs below. Ensure the UPS is connected to the Hospital Generator Power Supply. (Must Supply Brochure)

#	Specifications for UPS	Comply	Do not Comply	REFERENCE-PAGE BROCHURE /PARAGRAPH	NUMBER ON
1	Capacity : 3KVA /2400W				
2	Input Voltage: 220V/230 AC Single Phase				
3	Output Voltage: 220V/ 230V AC Single Phase				
4	Frequency : 50HZ up to 60HZ (auto sensing)				
5	Minimum 1 years replacement Guarantee				
6	Audible Alarm for Following Conditions: Main Failure Battery Low				
7	Overload Protection				
8	10ms Max transfer time on AC mode to/from battery mode . AC mode to/from bypass mode				
9	Bidder Must provide Manufacturer specification/brochure to confirm specification				

NHLS ALFRED NZO & JOE GQABI
MANAGEMENT & ADMIN OFFICE

1 2025 -06- 06

Name: Buyiswa Nolebe Sign: 

Approved ☒ Not Approved ☐