

#	Specifications for UPS	Comply	Do not Comply	REFERENCE-PAGE BROCHURE /PARAGRAPH	NUMBER ON
1	Capacity : 6KVA /2400W				
2	Input Voltage: 220V/230 AC Single Phase				
3	Output Voltage: 220V/ 230V AC Single Phase				
4	Frequency : 50HZ up to 60HZ (auto sensing)				
5	Minimum 1 years replacement Guarantee				
6	Audible Alarm for Following Conditions: Main Failure Battery Low				
7	Overload Protection				
8	10ms Max transfer time on AC mode to/from battery mode , AC mode to/from bypass mode				
9	Bidder Must provide Manufacturer specification/brochure to confirm specification				

and installation of UPS from Hospital Power to Network Cabinet.